

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT		DESIGN		CNSTRCTN		ELIGIBLE		STATIONING		STATION REFERENCE	COMMENTS	LAST UPDATE
			OK?	DATE	OK?	DATE	OK?	DATE	YES	DATE	SEC	TS R			

**Urban Drainage and Flood Control District Maintenance Eligibility Program
Status of Projects by Local Government**

Douglas County

17-Oct-2011

ARROWHEAD GULCH

3204	River Canyon		<input type="checkbox"/>	2/17/2004	<input type="checkbox"/>	2/17/2004	<input type="checkbox"/>		<input type="checkbox"/>	4/1/2004				2-7S-69W	1/14/02: Sketch plan. 5/5/03; plans & rpt. 2/17/04; plans & rpt. Stream stabilization, WQ Pond and flood attenuation do not meet District stds.	4/6/2004
3205	River Canyon		<input type="checkbox"/>	2/17/2004	<input type="checkbox"/>	2/17/2004	<input type="checkbox"/>		<input type="checkbox"/>	4/1/2004				11-7S-69W	1/14/02: Sketch plan. 5/5/03; plans & rpt. 2/17/04; plans & rpt. Stream stabilization, WQ Pond and flood attenuation do not meet District stds.	4/6/2004
2873	River Canyon		<input type="checkbox"/>	2/17/2004	<input type="checkbox"/>	2/17/2004	<input type="checkbox"/>		<input type="checkbox"/>	4/1/2004				34,35-6S-69W; 2,11-7S-69W	1/14/02: Sketch plan. 5/5/03; plans & rpt. 2/17/04; plans & rpt. Stream stabilization, WQ Pond and flood attenuation do not meet District stds.	2/17/2004
3206	River Canyon	Basin 7300	<input type="checkbox"/>	2/17/2004	<input type="checkbox"/>	2/17/2004	<input type="checkbox"/>		<input type="checkbox"/>	4/1/2004				34-6S-69W	1/14/02: Sketch plan. 5/5/03; plans & rpt. 2/17/04; plans & rpt. Stream stabilization, WQ Pond and flood attenuation do not meet District stds.	4/6/2004
2334	Roxborough Downs		<input checked="" type="checkbox"/>	12/4/1998	<input type="checkbox"/>	12/4/1998	<input type="checkbox"/>		<input type="checkbox"/>					2,11-7S-69W	See also 2136	12/7/1998
2136	Roxborough Downs 26th Amend. &	Un-named	<input checked="" type="checkbox"/>	12/4/1998	<input type="checkbox"/>	6/14/1999	<input type="checkbox"/>		<input type="checkbox"/>					2,11-7S-69W	AKA Project Area 5, see also 2334 6/14/99: minor revisions to 26th Amendment and Common Area D. Roxborough 26th Amendment will not be eligible until Common Area D is eligible.	6/17/1999

BADGER GULCH

3450	Meridian Int Bus Ctr (Meridian Villag		<input checked="" type="checkbox"/>	12/18/2007	<input checked="" type="checkbox"/>	12/18/2007	<input checked="" type="checkbox"/>	9/15/2010	<input type="checkbox"/>					18-6S-66W	213+00	246+00	Happy Canyon OSP	Lower Badger Gulch Drainageway Improvements. 5/8/07; plans and rpt.	9/15/2010
3532	Meridian Int Bus Ctr F 7D		<input checked="" type="checkbox"/>	9/17/2009	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>					18-6S-66W			Happy Canyon OSP	one outfall	2/15/2010
3248	Meridian Villages		<input type="checkbox"/>	8/16/2004	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>					18-6S-66W	198+00	239+50	Happy Canyon FHAD	8/16/04: plat.	8/25/2004
330	Rampart Range	un-named	<input checked="" type="checkbox"/>	10/2/1984	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>					24-6S-67W					9/3/1986

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT OK? DATE	DESIGN OK? DATE	CNSTRCTN OK? DATE	ELIGIBLE YES DATE	SEC TS R	STATIONING DS US	STATION REFERENCE	COMMENTS	LAST UPDATE
335	Rampart Range		<input checked="" type="checkbox"/> 10/2/1984	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	13,24-6S-67W	247+00 280+00	Happy Canyon Creek FHAD		9/3/1986
BALDWIN GULCH											
2094	Centennial Ranch		<input checked="" type="checkbox"/> 11/26/1997	<input checked="" type="checkbox"/> 5/28/1998	<input checked="" type="checkbox"/> 5/10/1999	<input checked="" type="checkbox"/> 1/17/2008	14-6S-66W	111+00 130+00	Happy Canyon et. al FHAD	11/8/96: Several problems. 8/26/97: Same. 11/26/97: incomplete const.drwgs.	1/17/2008
2773	Lincoln Avenue Extension Project	Pine Drive Diversion	<input type="checkbox"/> 3/29/2001	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	10,14,15-6S- 66W	0+00 8+00	Newlin & Baldwin Gulches OSP	See also 2771 & 2772	4/3/2001
2772	Lincoln Avenue Extension Project	Pine Drive Tributary	<input type="checkbox"/> 3/29/2001	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	10,15-6S-66W	0+00 2+00	Newlin & Baldwin Gulches OSP	See also 2771 & 2773	4/3/2001
2771	Lincoln Avenue Extension Project		<input type="checkbox"/> 3/29/2001	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	10,14,15-6S- 66W	70+00 101+00	Newlin & Baldwin Gulches OSP	See also 2772 & 2773	4/3/2001
687	Parker Baptist	unnamed	<input type="checkbox"/> 3/5/1981	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	11-6S-66W				10/2/1987
338	Parker-Hess		<input type="checkbox"/> 10/1/1984	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	10-6S-66W	40+00 69+00	Happy Canyon Creek FHAD		9/3/1986
588	Pine Lane Business Park		<input type="checkbox"/> 2/4/1987	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	9-6S-66W	0+00 19+50	Happy Canyon FHAD		2/6/1987
675	Wildwood Farm		<input type="checkbox"/> 1/25/1983	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	14-6S-66W	138+00 145+00	Baldwin Gulch FHAD		10/2/1987
BIG DRY CREEK (ARAPCO)											
1594	Carriage Club Estates		<input checked="" type="checkbox"/> 5/21/1996	<input checked="" type="checkbox"/> 3/16/1998	<input type="checkbox"/>	<input type="checkbox"/>	16-6S-67W	719+50 722+00	Big Dry Creek MP	Plan to dedicate FP to Douglas County for open space. One storm sewer outlet (Line C).	3/16/1998
3459	County Line Road, University to Colo	Tributary B	<input checked="" type="checkbox"/> 8/1/2007	<input checked="" type="checkbox"/> 8/1/2007	<input type="checkbox"/>	<input type="checkbox"/>	1-6S-68W			One roadway crossing, 7/31/07; mtg to discuss outlet, now ok. See also 2071 & 3458.	8/1/2007
3458	County Line Road, University to Colo	Otero	<input checked="" type="checkbox"/> 8/1/2007	<input checked="" type="checkbox"/> 8/1/2007	<input type="checkbox"/>	<input type="checkbox"/>	1-6S-68W			One roadway crossing, 7/31/07 mtg to discuss outlet and coordination with Otero Pond, now ok. See also 2071 & 3459.	8/1/2007
896	Creekside Business Park		<input checked="" type="checkbox"/> 12/23/1987	<input checked="" type="checkbox"/> 5/5/1998	<input type="checkbox"/>	<input type="checkbox"/>	6-6S-67W	490+00 505+00	Big Dry Creek FHAD	12/23/87: Includes fp area between County Line Rd. and C-470. 4/22/97: Site plan. Questions about ownership and maint.	5/11/1998
2181	Creekside Family Entertainment Cent		<input checked="" type="checkbox"/> 10/20/1997	<input checked="" type="checkbox"/> 12/8/1997	<input type="checkbox"/>	<input type="checkbox"/>	6-6S-67W	489+10 500+00	Big Dry Creek FHAD	Open floodplain and one storm sewer outlet.	12/8/1997

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT OK? DATE	DESIGN OK? DATE	CNSTRCTN OK? DATE	ELIGIBLE YES DATE	SEC TS R	STATIONING DS US	STATION REFERENCE	COMMENTS	LAST UPDATE
462	Highlands Ranch (72-A)	Meander Channel	<input checked="" type="checkbox"/> 11/6/1986	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	8,17-6S-67W	638+00 658+00	Big Dry Creek MP	Three storm sewer outfalls; maintenance questioned...	11/10/1986
965	Highlands Ranch (86-A)	unnamed (2)	<input type="checkbox"/> 7/29/1988	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	7-6S-67W				8/26/1988
1040	Highlands Ranch (86-C)	unnamed	<input checked="" type="checkbox"/> 11/16/1989	<input type="checkbox"/> 11/16/1989	<input type="checkbox"/>	<input checked="" type="checkbox"/> 6/26/2007	7-6S-67W			One Storm sewer outlet works only. After the fact review and acceptance.	7/9/2007
1051	Highlands Ranch (Plan #100)	unnamed (2)	<input checked="" type="checkbox"/> 2/13/1990	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-6S-68W			DA ?	2/19/1990
1052	Highlands Ranch (Plan #106)	unnamed	<input checked="" type="checkbox"/> 2/13/1990	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	7-6S-67W			DA ?	2/19/1990
763	Highlands Ranch (Plan #14)		<input checked="" type="checkbox"/> 6/12/1984	<input checked="" type="checkbox"/> 6/12/1984	<input type="checkbox"/>	<input type="checkbox"/> 9/7/2006	5-6S-67W	489+00 542+00	Big Dry Creek MP	In golf course. 9/7/06; repairs needed for final acceptance (see letter this date).	9/7/2006
762	Highlands Ranch (Plan #16)	unnamed	<input type="checkbox"/> 6/6/1984	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-6S-68W				10/12/1987
92	Highlands Ranch (Plan #61) Pipe 2 ex		<input checked="" type="checkbox"/> 8/18/1986	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> 6/26/2007	8-6S-67W	581+00 583+00	Big Dry Creek MP	Pipe 2 Ext from S.Quebec St.to Big Dry Ck. After the fact review and acceptance.	7/9/2007
212	Highlands Ranch (Plan #63)	un-named	<input type="checkbox"/> 12/9/1985	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-6S-68W			Master Detention Plan for PAs 3 & 74 approved (11/11/85);Sketch / Prelim. Plan #63 questioned...	6/11/1986
277	Highlands Ranch (Plan #67)		<input checked="" type="checkbox"/> 8/12/1986	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> 6/26/2007	5-6S-67W	532+00 555+00	Big Dry Creek MP	Three storm sewer outfalls. After the fact review and acceptance.	7/9/2007
513	Highlands Ranch (Plan #74)		<input type="checkbox"/> 12/1/1986	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	8-6S-67W	570+00 590+00	Big Dry Creek MP	Two storm sewer outfalls proposed; fp delineation appears incorrect; Dougco notified by phone; xref Plan #75 corr...	12/1/1986
514	Highlands Ranch (Plan #75)		<input checked="" type="checkbox"/> 11/25/1986	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	8-6S-67W	560+00 570+00	Big Dry Creek MP	Two storm sewer outfalls proposed...	12/1/1986
952	Highlands Ranch (Plan #90)		<input checked="" type="checkbox"/> 7/26/1988	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	8,17-6S-67W	664+00 670+00	Big Dry Creek MP	Two storm sewer outfalls...	7/28/1988
2521	Highlands Ranch Big Dry Creek Park		<input checked="" type="checkbox"/> 11/24/1999	<input checked="" type="checkbox"/> 4/7/2000	<input type="checkbox"/>	<input checked="" type="checkbox"/> 6/26/2007	7,18-6S-67W			Low flow trail crossing, drop and one storm sewer outfall. After the fact review and acceptance.	7/9/2007
2160	Highlands Ranch Channel Stab & Pon A		<input checked="" type="checkbox"/> 4/21/1999	<input checked="" type="checkbox"/> 11/22/2000	<input checked="" type="checkbox"/> 5/30/2003	<input type="checkbox"/>	18,19-6S-67W	1041+00 1143+00	Big Dry Cr. FHAD (1996)	See also 2161. 11/23/99: numerous design comments. Repair list 10.13.04.	5/30/2003
2161	Highlands Ranch Channel Stab & Pon Tributary to Tributary		<input checked="" type="checkbox"/> 4/21/1999	<input checked="" type="checkbox"/> 11/22/2000	<input checked="" type="checkbox"/> 5/30/2003	<input type="checkbox"/> 10/13/2004	18,19-6S-67W		Big Dry Cr. FHAD (1996)	See also 2160. 11/23/99: numerous design comments. Repair list 10.13.04.	10/13/2004
769	Highlands Ranch Culvert 1		<input checked="" type="checkbox"/> 6/28/1985	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> 6/26/2007	8-6S-67W	586+00 595+00	Big Dry Cr. MP	After the fact review and acceptance.	7/9/2007
764	Highlands Ranch Culvert 15		<input checked="" type="checkbox"/> 6/13/1984	<input checked="" type="checkbox"/> 8/6/1984	<input type="checkbox"/>	<input checked="" type="checkbox"/> 6/26/2007	5-6S-67W	540+00 542+00	Big Dry Creek MP	After the fact review and acceptance.	7/9/2007

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT OK? DATE	DESIGN OK? DATE	CNSTRCTN OK? DATE	ELIGIBLE YES DATE	SEC TS R	STATIONING DS US	STATION REFERENCE	COMMENTS	LAST UPDATE
770	Highlands Ranch Culvert 2	unnamed	<input checked="" type="checkbox"/> 6/28/1985	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> 6/26/2007	8-6S-67W			After the fact review and acceptance.	7/9/2007
1275	Highlands Ranch Culvert 28	unnamed	<input checked="" type="checkbox"/> 8/20/1992	<input checked="" type="checkbox"/> 8/20/1992	<input checked="" type="checkbox"/> 8/25/2004	<input checked="" type="checkbox"/> 8/25/2004	6-6S-67W			Energy dissipator only.	8/25/2004
1276	Highlands Ranch Culvert 29	unnamed	<input checked="" type="checkbox"/> 8/20/1992	<input checked="" type="checkbox"/> 8/20/1992	<input checked="" type="checkbox"/> 8/25/2004	<input checked="" type="checkbox"/> 8/25/2004	6-6S-67W			Energy dissipator only.	8/25/2004
1410	Highlands Ranch Culvert 30		<input checked="" type="checkbox"/> 12/7/1993	<input checked="" type="checkbox"/> 12/7/1993	<input checked="" type="checkbox"/> 7/7/1997	<input checked="" type="checkbox"/> 8/25/2004	7-6S-67W			Energy dissipator only.	8/25/2004
1288	Highlands Ranch Culvert 35	unnamed	<input checked="" type="checkbox"/> 10/1/1992	<input checked="" type="checkbox"/> 10/1/1992	<input checked="" type="checkbox"/> 9/27/1993	<input checked="" type="checkbox"/> 6/28/1996	7-6S-67W			Outlet protection only.	6/28/1996
1390	Highlands Ranch Culvert 37 & 38	Unnamed	<input checked="" type="checkbox"/> 10/7/1993	<input type="checkbox"/> 4/13/1994	<input type="checkbox"/>	<input checked="" type="checkbox"/> 6/26/2007	17-6S-67W			Two double box culverts.	7/9/2007
3154	Highlands Ranch Culvert 48		<input checked="" type="checkbox"/> 5/30/2003	<input checked="" type="checkbox"/> 5/30/2003	<input checked="" type="checkbox"/> 6/28/2006	<input checked="" type="checkbox"/> 6/28/2006	19-6S-68W			See also Highlands Ranch Filing 122 X.	6/28/2006
1074	Highlands Ranch Filing 109-A	unnamed	<input checked="" type="checkbox"/> 1/30/1992	<input type="checkbox"/> 1/30/1992	<input type="checkbox"/>	<input checked="" type="checkbox"/> 9/6/2006	6-6S-67W			9/6/06; After-the-fact review and acceptance based on 6/29/06 site visit.	9/6/2006
1323	Highlands Ranch Filing 109-D	unnamed	<input checked="" type="checkbox"/> 3/11/1993	<input checked="" type="checkbox"/> 3/11/1993	<input checked="" type="checkbox"/> 9/14/1995	<input checked="" type="checkbox"/> 8/25/2004	6-6S-67W			One energy dissipator.	8/25/2004
3153	Highlands Ranch Filing 122-Y Parcel	Un-named	<input checked="" type="checkbox"/> 10/20/2003	<input checked="" type="checkbox"/> 12/1/2003	<input checked="" type="checkbox"/> 8/26/2004	<input checked="" type="checkbox"/> 6/26/2006	18-6S-67W			Two storm sewer outfalls and one roadway crossing.	6/26/2006
979	Highlands Ranch Filing 86-A	un-named	<input checked="" type="checkbox"/> 11/15/1988	<input type="checkbox"/> 11/15/1988	<input type="checkbox"/>	<input checked="" type="checkbox"/> 6/26/2007	7-6S-67W			One storm sewer outfall. After the fact review and acceptance.	7/9/2007
1064	Highlands Ranch Filing 86-D	unnamed	<input checked="" type="checkbox"/> 4/27/1990	<input checked="" type="checkbox"/> 5/22/1990	<input checked="" type="checkbox"/> 3/27/1997	<input checked="" type="checkbox"/> 3/27/1997	7-6S-67W			Design approved as Filing 86-D & is now 86-E.	3/27/1997
1977	Highlands Ranch Filing No 126-A Pi		<input checked="" type="checkbox"/> 8/15/1995	<input checked="" type="checkbox"/> 10/5/1995	<input checked="" type="checkbox"/> 4/30/1996	<input checked="" type="checkbox"/> 7/6/1999	5-6S-67W			One storm sewer outlet.	7/6/1999
1351	Highlands Ranch Filing No. 100-E	Otero	<input checked="" type="checkbox"/> 7/19/1993	<input checked="" type="checkbox"/> 7/19/1993	<input checked="" type="checkbox"/> 1/4/1995	<input checked="" type="checkbox"/> 6/28/1996	1-6S-68W			One dissipator outletting into Pond 100.	6/28/1996
1364	Highlands Ranch Filing No. 100-K	unnamed	<input type="checkbox"/> 7/9/1993	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-6S-68W; 6-6S-67W			Inlet to Venneford Ranch Rd. detention pond.	7/13/1993
1284	Highlands Ranch Filing No. 106-B	unnamed	<input checked="" type="checkbox"/> 11/13/1992	<input checked="" type="checkbox"/> 11/13/1992	<input checked="" type="checkbox"/> 9/27/1993	<input checked="" type="checkbox"/> 3/10/1997	7-6S-67W			Two storm sewer outlets.	3/10/1997
1287	Highlands Ranch Filing No. 107-B	Unnamed	<input checked="" type="checkbox"/> 11/11/1992	<input checked="" type="checkbox"/> 11/11/1992	<input checked="" type="checkbox"/> 1/4/1995	<input checked="" type="checkbox"/> 9/6/2006	7-6S-67W			Two storm sewer outlets.	9/6/2006
1366	Highlands Ranch Filing No. 107-C	Unnamed	<input checked="" type="checkbox"/> 8/11/1993	<input checked="" type="checkbox"/> 8/11/1993	<input type="checkbox"/>	<input checked="" type="checkbox"/> 7/8/1999	7-6S-67W			One storm sewer outlet.	7/8/1999
1460	Highlands Ranch Filing No. 107-D	Unnamed	<input checked="" type="checkbox"/> 4/12/1994	<input checked="" type="checkbox"/> 4/12/1994	<input checked="" type="checkbox"/> 7/7/1997	<input checked="" type="checkbox"/> 9/6/2006	7-6S-67W			One outlet dissipator.	9/6/2006
1986	Highlands Ranch Filing No. 107-E	Un-named	<input checked="" type="checkbox"/> 8/29/1995	<input checked="" type="checkbox"/> 9/11/1995	<input checked="" type="checkbox"/> 1/10/2000	<input checked="" type="checkbox"/> 9/6/2006	7-6S-67W			Two storm sewer outlets.	9/6/2006
1319	Highlands Ranch Filing No. 109-C	West	<input type="checkbox"/> 2/2/1993	<input type="checkbox"/> 2/2/1993	<input type="checkbox"/>	<input checked="" type="checkbox"/> 6/26/2007	6-6S-67W			One storm sewer outlet. After the fact review and acceptance.	7/9/2007

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT OK? DATE	DESIGN OK? DATE	CNSTRCTN OK? DATE	ELIGIBLE YES DATE	SEC TS R	STATIONING DS US	STATION REFERENCE	COMMENTS	LAST UPDATE	
2203	Highlands Ranch Filing No. 109-E	unnamed	<input checked="" type="checkbox"/> 9/5/1997	<input type="checkbox"/> 9/5/1997	<input type="checkbox"/>	<input checked="" type="checkbox"/> 9/6/2006	6-6S-67W			One storm sewer outlet. 9/6/06; After-the-fact review and acceptance based on 6/29/06 site visit.	9/6/2006	
1391	Highlands Ranch Filing No. 117-A		<input checked="" type="checkbox"/> 10/7/1993	<input checked="" type="checkbox"/> 11/24/1993	<input type="checkbox"/>	<input checked="" type="checkbox"/> 6/26/2007	8-6S-67W			One energy dissipator "Dissipator A." After the fact review and acceptance.	7/9/2007	
1461	Highlands Ranch Filing No. 117-C		<input checked="" type="checkbox"/> 7/13/1994	<input checked="" type="checkbox"/> 7/13/1994	<input checked="" type="checkbox"/> 9/4/1996	<input checked="" type="checkbox"/> 3/10/1997	17-6S-67W	664+00	666+00	Big Dry Creek MP	Three storm sewer outfalls.	3/10/1997
1479	Highlands Ranch Filing No. 117-D	Unnamed	<input checked="" type="checkbox"/> 5/17/1994	<input checked="" type="checkbox"/> 7/20/1994	<input checked="" type="checkbox"/> 9/4/1996	<input checked="" type="checkbox"/> 3/10/1997	8-6S-67W				One storm sewer outlet. See also ID No. 1480.	3/10/1997
1558	Highlands Ranch Filing No. 117-E	Unnamed	<input checked="" type="checkbox"/> 4/17/1995	<input checked="" type="checkbox"/> 4/17/1995	<input checked="" type="checkbox"/> 7/8/1999	<input checked="" type="checkbox"/> 6/13/2006	17-6S-67W				Two storm sewer outlets.	6/13/2006
3177	Highlands Ranch Filing No. 122 W	Tributary C	<input checked="" type="checkbox"/> 10/21/2003	<input checked="" type="checkbox"/> 8/6/2004	<input checked="" type="checkbox"/> 8/3/2007	<input checked="" type="checkbox"/> 8/3/2007	19-6S-67W				Five storm sewer outfalls.	8/3/2007
2182	Highlands Ranch Filing No. 122-G		<input checked="" type="checkbox"/> 7/24/1997	<input checked="" type="checkbox"/> 7/24/1997	<input checked="" type="checkbox"/> 6/26/2006	<input checked="" type="checkbox"/> 6/26/2006	18-6S-67W				One storm sewer outlet.	6/26/2006
3013	Highlands Ranch Filing No. 122-V	Tributary C	<input checked="" type="checkbox"/> 3/25/2003	<input checked="" type="checkbox"/> 6/30/2003	<input checked="" type="checkbox"/> 6/25/2007	<input checked="" type="checkbox"/> 9/10/2007	18-6S-67W			Big Dry Cr. FHAD (1996)	Road crossing and 5 outfalls	9/10/2007
3155	Highlands Ranch Filing No. 122-X	Un-named	<input checked="" type="checkbox"/> 12/3/2003	<input checked="" type="checkbox"/> 12/3/2003	<input checked="" type="checkbox"/> 11/17/2008	<input checked="" type="checkbox"/> 11/17/2008	19-6S-67W				5/19/03; Plans & rpt. 8/22/03; plans & rpt. 5 outfalls and 2 culverts.	11/17/2008
3156	Highlands Ranch Filing No. 122-X	Tributary C	<input checked="" type="checkbox"/> 12/3/2003	<input checked="" type="checkbox"/> 12/3/2003	<input checked="" type="checkbox"/> 11/17/2008	<input checked="" type="checkbox"/> 11/17/2008	19-6S-67W				5/19/03; Plans & rpt. 8/22/03; plans & rpt.	11/17/2008
3107	Highlands Ranch Filing No. 122-Y	Un-named	<input checked="" type="checkbox"/> 2/27/2003	<input checked="" type="checkbox"/> 2/27/2003	<input checked="" type="checkbox"/> 7/2/2008	<input checked="" type="checkbox"/> 7/2/2008	24-6S-68W				Five storm sewer outfalls.	7/2/2008
2066	Highlands Ranch Filing No. 126-A Pi		<input checked="" type="checkbox"/> 11/27/1996	<input checked="" type="checkbox"/> 11/27/1996	<input checked="" type="checkbox"/> 5/27/1997	<input checked="" type="checkbox"/> 5/4/1999	5-6S-67W				One storm sewer outlet.	5/4/1999
2474	Highlands Ranch Filing No. 138	un-named	<input checked="" type="checkbox"/> 8/10/1999	<input checked="" type="checkbox"/> 2/11/2000	<input checked="" type="checkbox"/> 4/3/2003	<input checked="" type="checkbox"/> 4/3/2003	6-6S-67W				one storm sewer outfall	4/3/2003
1617	Highlands Ranch Filing No. 60-A	Otero	<input checked="" type="checkbox"/> 4/28/1995	<input checked="" type="checkbox"/> 6/15/1995	<input checked="" type="checkbox"/> 7/8/1999	<input type="checkbox"/> 9/7/2006	1-6S-68W				Two storm sewer outlets and fill in channel. 1/30/97: design changes being proposed for Otero detention #2071. 9/7/06; repairs needed for final acceptance (see letter this date).	9/7/2006
1283	Highlands Ranch Filing No. 90-C		<input checked="" type="checkbox"/> 10/1/1992	<input checked="" type="checkbox"/> 10/19/1992	<input checked="" type="checkbox"/> 9/27/1993	<input checked="" type="checkbox"/> 3/10/1997	17-6S-67W	655+00	675+00	Big Dry Creek MP	Two storm sewer outlets.	3/10/1997
2071	Highlands Ranch Otero Reg. Det. Pon	Otero	<input checked="" type="checkbox"/> 4/25/1997	<input checked="" type="checkbox"/> 5/15/1997	<input type="checkbox"/>	<input type="checkbox"/>	1-6S-68W				5/15/97: Eligibility won't be considered until future outlet completed along with construction of County Line Road.	5/15/1997
1522	Highlands Ranch Painters Park		<input checked="" type="checkbox"/> 10/5/1994	<input type="checkbox"/> 10/5/1994	<input type="checkbox"/>	<input checked="" type="checkbox"/> 6/26/2007	5-6S-67W				One storm sewer outlet. After the fact review and acceptance.	7/9/2007

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT OK? DATE	DESIGN OK? DATE	CNSTRCTN OK? DATE	ELIGIBLE YES DATE	SEC TS R	STATIONING DS US	STATION REFERENCE	COMMENTS	LAST UPDATE
2432	Highlands Ranch Pipe 108		<input checked="" type="checkbox"/> 11/4/1999	<input checked="" type="checkbox"/> 12/15/1999	<input checked="" type="checkbox"/> 11/29/2000	<input checked="" type="checkbox"/> 6/26/2007	5-6S-67W	517+00 517+00	Big Dry Creek MP	One storm sewer outfall. After the fact review and acceptance.	7/9/2007
1066	Highlands Ranch Pipe 5	unnamed	<input checked="" type="checkbox"/> 8/3/1990	<input checked="" type="checkbox"/> 8/3/1990	<input checked="" type="checkbox"/> 10/4/1993	<input checked="" type="checkbox"/> 6/13/2006	7-6S-67W				6/13/2006
1068	Highlands Ranch Pipe 6	unnamed	<input checked="" type="checkbox"/> 5/22/1990	<input checked="" type="checkbox"/> 5/22/1990	<input checked="" type="checkbox"/> 10/4/1993	<input checked="" type="checkbox"/> 9/6/2006	7-5S-67W			Outlet dissipator only.	10/4/1993
1277	Highlands Ranch Pipe 65	unnamed	<input checked="" type="checkbox"/> 8/20/1992	<input checked="" type="checkbox"/> 8/20/1992	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> 9/6/2006	6-6S-67W			Energy dissipator only. 9/6/06; After-the-fact review and acceptance based on 6/29/06 site visit.	9/6/2006
1330	Highlands Ranch Pipe 75	Otero	<input checked="" type="checkbox"/> 7/19/1993	<input checked="" type="checkbox"/> 7/19/1993	<input type="checkbox"/> 3/10/1994	<input type="checkbox"/> 3/10/1994	1-6S-68W			Built w/o telling us.	3/10/1994
1329	Highlands Ranch Pond 100	Otero	<input checked="" type="checkbox"/> 7/19/1993	<input checked="" type="checkbox"/> 7/19/1993	<input type="checkbox"/> 3/10/1994	<input type="checkbox"/> 3/10/1994	1-6S-68W			Built w/o telling us.	3/10/1994
3495	Highlands Ranch Pond 21 N9 Park	Tributary to Tributary	<input checked="" type="checkbox"/> 6/11/2008	<input checked="" type="checkbox"/> 6/11/2008	<input checked="" type="checkbox"/> 5/28/2009	<input type="checkbox"/>	18,19-6S-67W		Big Dry Cr. FHAD (1996)	2/21/08 Park development within pond.	5/28/2009
1451	Highlands Ranch S. Colorado Blvd. 1	Unnamed	<input checked="" type="checkbox"/> 3/2/1994	<input checked="" type="checkbox"/> 3/2/1994	<input type="checkbox"/> 1/11/1995	<input type="checkbox"/>	1-6S-68W			Storm sewer outlet to detention pond.	1/13/1995
1214	Highlands Ranch Sketch Plan 117		<input checked="" type="checkbox"/> 11/19/1991	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	8,17-6S-67W	622+00 680+00	Big Dry Creek MP		12/4/1991
1215	Highlands Ranch Sketch Plan 117	Un-named	<input checked="" type="checkbox"/> 11/19/1991	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	8,17-6S-67W				12/4/1991
1313	Highlands Ranch Venneford Ranch R	Unnamed	<input checked="" type="checkbox"/> 12/31/1992	<input checked="" type="checkbox"/> 2/9/1993	<input checked="" type="checkbox"/> 4/20/2000	<input checked="" type="checkbox"/> 4/20/2000	1-6S-68W; 6-6S-67W			Detention pond and inlet and outlet structures. 4/20/2000: After the fact deletion of trickle channel. DO NOT DO MAINT RELATED TO LACK OF TRICKLE CHANNEL.	4/20/2000
34	Highlands Vista	and 2 trib.	<input checked="" type="checkbox"/> 1/9/1986	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	17,20-6S-67W	703+00 719+50	Big Dry Creek MP		4/24/1986
1346	Intravest 320		<input checked="" type="checkbox"/> 5/28/1993	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	17-6S-67W	703+00 719+50	Big Dry Creek (ARAPCO) MP		6/3/1993
1347	Intravest 320 (aka Wildcat Ridge 1 &	Unnamed	<input checked="" type="checkbox"/> 5/28/1993	<input type="checkbox"/> 2/15/1994	<input type="checkbox"/>	<input type="checkbox"/>	17,20-6S-67W			Six storm sewer outlets.	2/15/1994
1442	Intravest 320 (aka Wildcat Ridge 1 &	unnamed	<input checked="" type="checkbox"/> 5/28/1993	<input type="checkbox"/> 2/15/1994	<input type="checkbox"/> 2/15/1995	<input type="checkbox"/> 2/15/1995	20-6S-67W			Detention pond already built in Park M w/o District O.K.	10/9/1995
1570	Intravest 320 Filing 1-D	Unnamed	<input checked="" type="checkbox"/> 4/19/1995	<input checked="" type="checkbox"/> 4/19/1995	<input checked="" type="checkbox"/> 1/9/1996	<input checked="" type="checkbox"/> 5/16/1996	17-6S-67W			One storm sewer outlet dissipator.	5/16/1996
2060	Intravest 320 Filing No. 1-M	Un-named	<input type="checkbox"/> 7/1/1996	<input type="checkbox"/> 7/1/1996	<input type="checkbox"/>	<input type="checkbox"/> 7/1/1996	17-6S-67W			Diversion of trib. in a pipe. Not eligible by definition. One pipe outlet. Reaffirmed this in note to the county on 9/26/96. 2/11/97: Reaffirmed to county that this filing is not eligible.	2/11/1997

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT OK? DATE	DESIGN OK? DATE	CNSTRCTN OK? DATE	ELIGIBLE YES DATE	SEC TS R	STATIONING DS US	STATION REFERENCE	COMMENTS	LAST UPDATE	
1441	Intravest 320 Filings 1A & 1B	unnamed	<input checked="" type="checkbox"/> 5/28/1993	<input checked="" type="checkbox"/> 5/17/1994	<input checked="" type="checkbox"/> 10/9/1995	<input checked="" type="checkbox"/> 9/16/1997	17-6S-67W			Detention pond in Park B.	9/16/1997	
1454	Intravest 320 Filings 1A & 1B	Unnamed	<input checked="" type="checkbox"/> 2/15/1994	<input checked="" type="checkbox"/> 4/28/1994	<input checked="" type="checkbox"/> 10/9/1995	<input checked="" type="checkbox"/> 9/16/1997	17,20-6S-67W			Five storm sewer outlets, four into Park M.	9/16/1997	
1508	Intravest Filing 1C	unnamed	<input type="checkbox"/> 8/26/1994	<input type="checkbox"/> 8/26/1994	<input type="checkbox"/>	<input type="checkbox"/> 11/18/1994	17-6S-67W			Large basin diversion. Not eligible by definition.	11/21/1994	
2301	McArthur Ranch Filing No. 4		<input checked="" type="checkbox"/> 8/10/1998	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	21-6S-67W	754+00	766+50	Big Dry FHAD (1996)	Rezoning. Floodplain in area to be a park.	8/10/1998
684	Mission Ridge	unnamed	<input type="checkbox"/> 9/25/1980	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	21-6S-67W			Two unnamed tribs.	10/2/1987	
1636	Province Center	Otero	<input checked="" type="checkbox"/> 6/26/1995	<input checked="" type="checkbox"/> 6/26/1995	<input checked="" type="checkbox"/> 6/3/1997	<input checked="" type="checkbox"/> 6/3/2002	6-6S-67W			Two storm sewer outlets. See also #1405.	6/5/2002	
3208	Province Center Filing No. 1-A	Otero	<input checked="" type="checkbox"/> 4/6/2004	<input checked="" type="checkbox"/> 5/24/2005	<input checked="" type="checkbox"/> 7/11/2007	<input checked="" type="checkbox"/> 7/11/2007	6-6S-67W			One storm sewer outlet. 4/6/05; plans & rpt. 3/9/05; plans & rpt. 4/29/05; plans & rpt.	7/11/2007	
1405	Province Center Filing No. 1-C	Otero	<input checked="" type="checkbox"/> 11/30/1993	<input checked="" type="checkbox"/> 8/30/1995	<input checked="" type="checkbox"/> 8/26/1996	<input checked="" type="checkbox"/> 6/2/2003	6-6S-67W			One storm sewer outlet. See #1636.	6/2/2003	
1144	Shadow Canyon (470 Frontage Comp	un-named	<input checked="" type="checkbox"/> 4/17/2003	<input checked="" type="checkbox"/> 5/30/2003	<input checked="" type="checkbox"/> 9/24/2007	<input checked="" type="checkbox"/> 9/24/2007	6-6S-67W			1/15/91; Rezoning only. 8/9/99; revised rezoning. 3/26/03; plans & rpt. 4/17/03; plans & rpt.	9/24/2007	
BIG DRY CREEK (ARAPCO) BR												
1389	Highlands Ranch Filing No. 117-A		<input checked="" type="checkbox"/> 10/7/1993	<input checked="" type="checkbox"/> 11/24/1993	<input checked="" type="checkbox"/> 9/14/1995	<input checked="" type="checkbox"/> 6/28/1996	7-6S-67W			One energy dissipator "Dissipator B."	6/28/1996	
1468	Highlands Ranch Filing No. 117-B		<input checked="" type="checkbox"/> 5/23/1994	<input checked="" type="checkbox"/> 5/23/1994	<input checked="" type="checkbox"/> 9/4/1996	<input checked="" type="checkbox"/> 6/13/2006	18-6S-67W			Two storm sewer outfalls.	6/13/2006	
1480	Highlands Ranch Filing No. 117-D		<input checked="" type="checkbox"/> 5/17/1994	<input checked="" type="checkbox"/> 7/20/1994	<input checked="" type="checkbox"/> 9/4/1996	<input checked="" type="checkbox"/> 3/10/1997	7-6S-67W			One storm sewer outlet. See also ID No. 1479.	3/10/1997	
1553	Highlands Ranch Filing No. 117-F		<input checked="" type="checkbox"/> 11/21/1994	<input checked="" type="checkbox"/> 11/21/1994	<input checked="" type="checkbox"/> 9/4/1996	<input checked="" type="checkbox"/> 6/13/2006	18-6S-67W			One storm sewer outlet.	6/13/2006	
1505	Highlands Ranch Filing No. 120-A		<input checked="" type="checkbox"/> 8/26/1994	<input checked="" type="checkbox"/> 3/14/1995	<input checked="" type="checkbox"/> 9/4/1996	<input checked="" type="checkbox"/> 9/1/1998	7,8-6S-67W			Two storm sewer outlet dissipaters.	9/1/1998	
1574	Highlands Ranch Filing No. 120-B Pi		<input checked="" type="checkbox"/> 9/22/1995	<input checked="" type="checkbox"/> 9/22/1995	<input checked="" type="checkbox"/> 5/4/1999	<input checked="" type="checkbox"/> 5/4/1999	7,18-6S-67W			One storm sewer outlet.	5/4/1999	
2221	Highlands Ranch Filing No. 122-H		<input checked="" type="checkbox"/> 11/6/1997	<input checked="" type="checkbox"/> 11/6/1997	<input checked="" type="checkbox"/> 4/3/2003	<input checked="" type="checkbox"/> 4/3/2003	18-6S-67W			Three storm sewer outlets.	4/3/2003	
2536	Highlands Ranch Filing No. 122-Q		<input checked="" type="checkbox"/> 4/18/2000	<input checked="" type="checkbox"/> 7/17/2000	<input checked="" type="checkbox"/> 8/25/2004	<input checked="" type="checkbox"/> 6/26/2006	18,19-6S-67W			Three storm sewer outfalls.	6/26/2006	
2623	Highlands Ranch Filing No. 122-U	un-named	<input checked="" type="checkbox"/> 6/29/2000	<input checked="" type="checkbox"/> 6/29/2000	<input checked="" type="checkbox"/> 11/30/2004	<input checked="" type="checkbox"/> 7/11/2007	24-6S-68W			6/29/00; supplemental report & plans for one storm sewer outfall. 6/8/06; waiting on revegetation.	7/11/2007	

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT OK? DATE	DESIGN OK? DATE	CNSTRCTN OK? DATE	ELIGIBLE YES DATE	SEC TS R	STATIONING DS US	STATION REFERENCE	COMMENTS	LAST UPDATE	
2424	Highlands Ranch Griggs Road	Unnamed	<input checked="" type="checkbox"/> 3/8/2000	<input checked="" type="checkbox"/> 4/11/2000	<input checked="" type="checkbox"/> 8/26/2004	<input checked="" type="checkbox"/> 8/26/2004	19-6S-67W			4/20/99: Grade control structures and culvert outlet. 8/10/99: not yet comfortable with outlet proposal (trying to avoid an impact basin). 10/14/99: no progress. 3/8/00: construction details.	8/26/2004	
CHEROKEE MOUNTAIN DRAIN												
3386	Ready Mix Concrete (Owens Indus Pa		<input type="checkbox"/> 2/6/2006	<input type="checkbox"/> 5/22/2006	<input type="checkbox"/>	<input type="checkbox"/>	3-7S-68W	1000+00	1019+50	Plum Creek FHAD (11/01)	2/6/06: SIP. Ignores MP. 5/22/06; plans & rpt, still ignores MP & NFIP requirements.	5/22/2006
CHERRY CREEK												
698	Briarwood	unnamed (several)	<input type="checkbox"/> 11/3/1981	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3-6S-66W					10/5/1987
699	Canyon Ranch Estates		<input checked="" type="checkbox"/> 5/8/1978	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	21-6S-66W	1292+00	1340+00	Cherry Creek FPI	Grandfathered in	10/5/1987
685	Cherry Park		<input checked="" type="checkbox"/> 2/19/1981	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	9-6S-66W	1192+50	1204+00	Cherry Creek FPI	Leaving FP open. Could be eligible if Dougco asks.	10/2/1987
3364	Choke Cherry Farm		<input checked="" type="checkbox"/> 9/6/2005	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	15-7S-65W	1712+00	1780+00	Cherry Creek FHAD	9/6/05: Comp plan amendment.	9/6/2005
719	Cottonwood #2		<input checked="" type="checkbox"/> 3/12/1984	<input checked="" type="checkbox"/> 3/12/1984	<input type="checkbox"/>	<input type="checkbox"/>	4-6S-66W	1115+00	1125+00	Cherry Creek FPI	After-the-fact erosion protection for filing #2. Has been built. We did not have the opportunity to observe the work. Will be beefed up by Parker during construction of a new bridge at Cottonwood Dr.	10/6/1987
714	Cottonwood #3	unnamed	<input type="checkbox"/> 2/17/1982	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5-6S-66W				Proposed channel south of Filing 3.	10/5/1987
717	Cottonwood #7	unnamed	<input type="checkbox"/> 11/12/1982	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4,5-6S-66W					10/5/1987
718	Cottonwood #8	unnamed	<input checked="" type="checkbox"/> 11/22/1983	<input checked="" type="checkbox"/> 11/22/1983	<input type="checkbox"/>	<input type="checkbox"/>	4-6S-66W					10/5/1987
360	Cottonwood Filing No. 10	2 tribs.	<input checked="" type="checkbox"/> 8/6/1986	<input checked="" type="checkbox"/> 8/29/1994	<input checked="" type="checkbox"/> 12/30/1996	<input checked="" type="checkbox"/> 3/11/1997	4,5-6S-66W				Two channels.	3/11/1997
1633	Cottonwood Filing No. 11	Un-named	<input checked="" type="checkbox"/> 9/1/1995	<input checked="" type="checkbox"/> 9/1/1995	<input checked="" type="checkbox"/> 9/18/1998	<input checked="" type="checkbox"/> 6/27/2001	5-6S-66W				Channel w/drop structures and Det Pond.	6/27/2001
710	Cottonwood Phase A		<input checked="" type="checkbox"/> 12/31/1980	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4-6S-66W	1086+00	1115+00	Cherry Creek FPI	Right bank floodplain set aside for park. Could be eligible if county asks.	10/5/1987
712	Cottonwood Phase B		<input checked="" type="checkbox"/> 5/12/1981	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4-6S-66W	1115+00	1125+00	Cherry Creek FPI	Right bank only. Set aside as park. Was later ripped up by developer. Now being looked at by Parker as part of bridge project. UDFCD may participate in const. costs.	10/5/1987

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT		DESIGN		CNSTRCTN		ELIGIBLE		STATIONING		STATION REFERENCE	COMMENTS	LAST UPDATE	
			OK?	DATE	OK?	DATE	OK?	DATE	YES	DATE	SEC	TS R				DS
713	Cottonwood Phase C		<input checked="" type="checkbox"/>	1/5/1982	<input type="checkbox"/>		<input type="checkbox"/>				4,5-6S-66W	1071+50	1086+00	Cherry Creek FPI	Left bank floodplain left as park. Could be eligible if county would ask.	10/5/1987
716	Cottonwood Phase E	unnamed	<input type="checkbox"/>	7/8/1982	<input type="checkbox"/>		<input type="checkbox"/>				4-6S-66W					10/5/1987
715	Cottonwood Phase E		<input checked="" type="checkbox"/>	7/8/1982	<input type="checkbox"/>		<input type="checkbox"/>				4,5-6S-66W	1086+00	1125+00	Cherry Creek FPI	Left bank floodplain set aside for park use.	10/5/1987
704	Cottonwood Valley		<input type="checkbox"/>	1/27/1983	<input type="checkbox"/>		<input type="checkbox"/>				9-6S-66W	1141+00	1185+00	Cherry Creek FPI		10/5/1987
337	Crown Pointe	3 tribs.	<input type="checkbox"/>	2/8/1985	<input type="checkbox"/>		<input type="checkbox"/>				3,4,10-6S-66W					9/3/1986
907	E-470 Bridges @ Cherry Creek		<input type="checkbox"/>	12/29/1987	<input type="checkbox"/>		<input type="checkbox"/>				9-6S-66W	1140+00	1185+00	Cherry Creek FPI	Proposes large increase in 100-yr profile. Needs close look.	1/5/1988
2739	E-470 Maintenance Facility	unnamed	<input checked="" type="checkbox"/>	1/22/2001	<input type="checkbox"/>	1/22/2001	<input type="checkbox"/>				8-6S-66W				See also 2425, Stonegate WWTP. Road crossing & one outfall.	1/23/2001
1632	Fox Crossing		<input type="checkbox"/>	5/23/1995	<input type="checkbox"/>		<input type="checkbox"/>				28-4S-67W				One storm sewer outlet.	5/25/1995
1050	Highlands Ranch (Plan #105)		<input checked="" type="checkbox"/>	2/13/1990	<input type="checkbox"/>		<input type="checkbox"/>				8-6S-68W	104+00	108+00	Marcy Gulch FHAD		2/19/1990
2988	Lafarge West Concrete Batch Plant	Apache Plume Reach	<input type="checkbox"/>	6/17/2002	<input type="checkbox"/>		<input type="checkbox"/>				8-6S-66W	9+00	17+50	Cottonwood OSP	6/17/02: Use by Special Review.	6/17/2002
562	Lundieck-Clarke-Winslow	un-named	<input checked="" type="checkbox"/>	12/9/1986	<input type="checkbox"/>		<input type="checkbox"/>				4-6S-66W					1/9/1987
589	Pine Lane Business Park		<input type="checkbox"/>	2/4/1987	<input type="checkbox"/>		<input type="checkbox"/>				9-6S-66W	1184+50	1197+50	Cherry Creek FPI		2/6/1987
1407	Pinery NW		<input type="checkbox"/>	8/24/1995	<input type="checkbox"/>		<input type="checkbox"/>				3,10-7S-66W	1557+00	1627+00	Cherry Creek FPI	Sketch Plan and rezone.	8/29/1995
1987	Pinery NW	Un-named	<input type="checkbox"/>	8/24/1995	<input type="checkbox"/>		<input type="checkbox"/>				3,10-7S-66W				Sketch Plan and rezone.	8/29/1995
1604	Pinery SW Filing No. 1-A	Three unnamed	<input type="checkbox"/>	6/22/2000	<input type="checkbox"/>	6/22/2000	<input type="checkbox"/>				15,16-7S-66W				See also ID #1603. 5/9/97: Formerly Berkshire Crossing. 1/27/99: still asking whether applicant desires maintenance eligibility. 6/22/00; study, bridge & grading plans, same fp problems.	6/26/2000
1603	Pinery SW Filing No. 1-A		<input type="checkbox"/>	6/22/2000	<input type="checkbox"/>	6/22/2000	<input type="checkbox"/>				15-7S-66W	1687+00	1754+00	Cherry Creek FPI	See also ID #1604. 5/9/97: Formerly Berkshire Crossing. Plat covers basically east half of floodplain. 2/4/99: numerous floodplain problems. 6/22/00; study, bridge & grading plans, same fp problems.	6/26/2000
3446	Pinery West		<input checked="" type="checkbox"/>	5/1/2007	<input type="checkbox"/>		<input type="checkbox"/>				10-7S-66W	1611+00	1689+00	Cherry Cr FHAD 2003	Sketch Plan #2. FP preservation.	5/1/2007
2995	Pinery West District Roads	Un-named	<input checked="" type="checkbox"/>	6/12/2002	<input checked="" type="checkbox"/>	6/12/2002	<input checked="" type="checkbox"/>	6/21/2004	<input checked="" type="checkbox"/>	6/21/2004	16-7S-66W				Bayou Gulch Road storm sewer outfall.	6/21/2004
3560	Pinery West Filing 2 - Fonder Draw	Founder Draw	<input checked="" type="checkbox"/>	8/31/2010	<input checked="" type="checkbox"/>	4/18/2011	<input type="checkbox"/>				10-7S-66W				7 check structures and culvert crossing	4/18/2011

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT OK? DATE	DESIGN OK? DATE	CNSTRCTN OK? DATE	ELIGIBLE YES DATE	SEC TS R	STATIONING DS US	STATION REFERENCE	COMMENTS	LAST UPDATE	
2712	Pinery West Jordan/Chambers Parkwa		<input checked="" type="checkbox"/> 11/7/2000	<input checked="" type="checkbox"/> 8/23/2001	<input checked="" type="checkbox"/> 6/21/2004	<input checked="" type="checkbox"/> 8/20/2007	15-7S-66W			11/7/00; const plans, trail plans, bridge hydraulics, & soils report. 5/31/01; const plans, minor problems.	8/20/2007	
2970	Pinery West Ponds C3 & C4	Un-named	<input checked="" type="checkbox"/> 3/27/2002	<input checked="" type="checkbox"/> 6/12/2002	<input checked="" type="checkbox"/> 6/1/2005	<input type="checkbox"/>	15-7S-66W			Pond C4 is eligible, Pond C3 is not a major facility. See also record 2995.	6/1/2005	
696	Stonegate		<input type="checkbox"/> 4/21/1982	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	16-6S-66W	1213+50	1245+00	Cherry Creek FPI	10/5/1987	
219	Stonegate		<input checked="" type="checkbox"/> 5/10/1985	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	16-6S-66W	1210+00	1240+00	Cherry Creek FPI	6/11/1986	
3080	Stonegate Basin A Jordan Road CBC	Un-named	<input checked="" type="checkbox"/> 12/18/2002	<input checked="" type="checkbox"/> 12/18/2002	<input type="checkbox"/>	<input type="checkbox"/>	8-6S-66W			See also 2549. Open channel changed to CBC adj to Jordan Road.	1/2/2003	
2954	Stonegate Filing 27 1st Amendment	Apache Plume Reach	<input type="checkbox"/> 3/15/2002	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	8-6S-66W	8+60	18+00	Cottonwood OSP	3/15/02: Amendment	3/15/2002
2549	Stonegate Filing No. 14	Un-named	<input checked="" type="checkbox"/> 9/22/2000	<input checked="" type="checkbox"/> 11/15/2001	<input checked="" type="checkbox"/> 4/6/2009	<input checked="" type="checkbox"/> 4/6/2009	8-6S-66W			See also 2495, Ponds 2A, 2B & 5; channels A1.1 & A1.2. Pond 5 will be treated as a wetland bottom pond.	4/6/2009	
3040	Stonegate Filing No. 14 A	Un-named	<input checked="" type="checkbox"/> 10/2/2002	<input checked="" type="checkbox"/> 10/2/2002	<input checked="" type="checkbox"/> 4/9/2009	<input checked="" type="checkbox"/> 4/9/2009	8-6S-66W			one storm sewer outfall to Channel A. 10/2/02; const plans & rpt.	4/9/2009	
3063	Stonegate Filing No. 14 B Communit	Un-named	<input checked="" type="checkbox"/> 11/13/2002	<input checked="" type="checkbox"/> 12/18/2002	<input checked="" type="checkbox"/> 4/9/2009	<input checked="" type="checkbox"/> 4/9/2009	8-6S-66W			One storm sewer outfall. (No longer outfalls direct.)	4/9/2009	
1618	Stonegate Filing No. 21-B		<input checked="" type="checkbox"/> 4/28/1995	<input type="checkbox"/> 4/28/1995	<input type="checkbox"/>	<input type="checkbox"/>	16-6S-66W			One storm sewer outlet.	5/5/1995	
2004	Stonegate Filing No. 8-A	A-1	<input type="checkbox"/> 10/17/1995	<input type="checkbox"/> 3/4/1996	<input type="checkbox"/>	<input type="checkbox"/>	8-6S-66W			Detention Pond 2. Not on any District master plan. Not regional but on-site.	3/4/1996	
2972	Stonegate Filing Nos. 20 & 22	Un-named	<input type="checkbox"/> 1/23/2002	<input type="checkbox"/> 4/24/2002	<input type="checkbox"/>	<input type="checkbox"/> 7/22/2002	8-6S-66W			The Market at Stonegate, see also Record 2971. Outfall to Pond 6. 1/23/02; const plans & rpt. 4/24/02; const plans & rpt. 7/22/02; temp drop & pond not eligible until permanent approved const done.	7/22/2002	
2971	Stonegate Filing Nos. 20 & 22	Un-named	<input checked="" type="checkbox"/> 1/23/2002	<input checked="" type="checkbox"/> 7/22/2002	<input checked="" type="checkbox"/> 4/6/2009	<input checked="" type="checkbox"/> 4/6/2009	8-6S-66W			The Market at Stonegate, see also Record 2972. Outfall to Pond 5. 1/23/02; const plans & rpt. 4/24/02; const plans & rpt	4/6/2009	
2495	Stonegate Village Arterial Roads	Un-named	<input type="checkbox"/> 2/11/2000	<input type="checkbox"/> 2/11/2000	<input type="checkbox"/>	<input type="checkbox"/>	8-6S-66W			See also 2494, 2549 & 2626, one roadway crossing (6x4 cbc extension). 2/11/00: needs coordination with Filing 14 master plan. 5/23/00; temporary facilities for now	2/11/2000	
2425	Stonegate Wastewater Treatment Plan	Unnamed	<input checked="" type="checkbox"/> 9/15/1999	<input checked="" type="checkbox"/> 11/3/1999	<input checked="" type="checkbox"/> 12/2/2002	<input checked="" type="checkbox"/> 8/28/2007	8-6S-66W			4/20/99: Sketch plan and drainage report.	8/28/2007	

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT		DESIGN		CNSTRCTN		ELIGIBLE		STATIONING		STATION REFERENCE	COMMENTS	LAST UPDATE
			OK?	DATE	OK?	DATE	OK?	DATE	YES	DATE	SEC	TS R			
COTTONWOOD CREEK (ARAP)															
10	Bradbury 267		<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>		2-6S-67W	215+00	244+00	Cottonwood Creek FHAD	3/3/1986
1167	Bradbury Section 2		<input type="checkbox"/>	6/7/1991	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>		2-6S-67W	215+00	244+25	Piney Creek FHAD	6/14/1991
1039	E-470 Bridges @ Cottonwood Creek		<input type="checkbox"/>	11/3/1989	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>		2-6S-67W	225+00	240+00	Piney Creek FHAD	Construction by E-470 Authority. 12/11/1989
908	E-470 bridges at Cottonwood Creek		<input type="checkbox"/>	1/6/1988	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>		2-6S-67W	226+00	241+00	Cottonwood Creek FHAD	1/12/1988
2025	Inverness - Georgia Pacific		<input checked="" type="checkbox"/>	12/13/1995	<input type="checkbox"/>	12/13/1995	<input type="checkbox"/>		<input type="checkbox"/>	2/12/2008	2-6S-67W			One storm sewer outlet. Install concrete headwall on pipe to be eligible -see repair list dated 1/22/08.	2/12/2008
734	Inverness #6		<input type="checkbox"/>	8/12/1983	<input type="checkbox"/>	8/12/1983	<input type="checkbox"/>		<input type="checkbox"/>		2-6S-67W	187+50	202+00	Piney Creek FHAD	10/6/1987
735	Inverness Business Park Filing No. 7		<input checked="" type="checkbox"/>	8/22/2000	<input type="checkbox"/>	8/22/2000	<input type="checkbox"/>		<input type="checkbox"/>		2-6S-67W	202+00	218+00	Piney Creek FHAD	See also 2744. One storm sewer outfall to South Sedimentation Pond. 8/29/2000
3207	Inverness Business Park Gates Fluid		<input checked="" type="checkbox"/>	4/1/2004	<input checked="" type="checkbox"/>	7/13/2004	<input type="checkbox"/>		<input type="checkbox"/>		2-6S-67W			4/1/04; plans & rpt.	7/13/2004
2001	Inverness Drive South Bridge		<input checked="" type="checkbox"/>	10/13/1995	<input type="checkbox"/>		<input type="checkbox"/>		<input checked="" type="checkbox"/>	9/25/2007	2-6S-67W	205+00	215+00	Piney Cr. FHAD	See also 2744. Inverness Drive South bridge crossing. Existing GSB drop thru bridge had cncpt appr 10/13/95, but not des appr. 9/25/2007
2744	Inverness South Sedimentation Pond		<input type="checkbox"/>	2/1/2001	<input type="checkbox"/>	2/1/2001	<input type="checkbox"/>		<input type="checkbox"/>	5/22/2001	2-6S-67W			See also 735 & 2001. 1/14/00; floodplain study, CLORM 12/23/99 based on u/s channel excavation & FP fill. 2/1/01; const plans. 5/22/01; see letter this date. 6/15/2001	
940	Meridian		<input checked="" type="checkbox"/>	6/9/1988	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>		11-6S-67W	244+00	300+00	Cottonwood Creek FHAD	8/31/1988
1139	Meridian 1990		<input checked="" type="checkbox"/>	12/31/1990	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>		2-6S-67W	235+00	244+00	Piney Creek FHAD	Rezoning only. 1/2/1991
2672	Meridian Internat'l Business Ctr Flg 7		<input checked="" type="checkbox"/>	7/9/1999	<input type="checkbox"/>	11/17/2005	<input type="checkbox"/>		<input type="checkbox"/>		13-6S-67W			7/9/99: Adding property to PD. Say they will stay out of floodplain. 6/29/00; study & plans, very preliminary. 8/22/00; phase 2 study should address stream stability & road crossing. 11/17/05; plan 11/17/2005	
2673	Meridian Office Park Flg 1, 21st Ame		<input type="checkbox"/>	8/22/2000	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>		2,3,10-6S-67W; 11-6S-67W			8/22/00; study, floodplain preservation, on-line detention with no details. 8/29/2000	

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT OK? DATE	DESIGN OK? DATE	CNSTRCTN OK? DATE	ELIGIBLE YES DATE	SEC TS R	STATIONING DS US	STATION REFERENCE	COMMENTS	LAST UPDATE
333	Rampart Range		<input checked="" type="checkbox"/> 10/2/1984	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	14,15,22-6S-67W	301+00 396+00	Piney Creek FHAD		9/3/1986
DAD CLARK GULCH											
723	Broadway & Plaza Drive Culverts		<input checked="" type="checkbox"/> 7/30/1980	<input checked="" type="checkbox"/> 9/26/1980	<input type="checkbox"/>	<input checked="" type="checkbox"/> 9/7/2006	3-6S-68W	158+00 162+00	Dad Clark Gulch FHAD	Filed under Mission Viejo off site. 9/7/06; After-the-fact review and acceptance based on 7/27/06 site visit.	9/7/2006
724	Broadway & Plaza Drive Culverts		<input checked="" type="checkbox"/> 7/30/1980	<input checked="" type="checkbox"/> 9/26/1980	<input type="checkbox"/>	<input checked="" type="checkbox"/> 9/7/2006	3-6S-66W	131+00 135+00	Dad Clark Gulch FHAD	Filed under Mission Viejo off site. 9/7/06; After-the-fact review and acceptance based on 7/27/06 site visit.	9/7/2006
3535	County Line/Lucent Regional Pond		<input checked="" type="checkbox"/> 10/5/2010	<input checked="" type="checkbox"/> 10/5/2010	<input type="checkbox"/>	<input type="checkbox"/>	3,4-6S-68W		Dad Clark Gulch FHAD	Outlet structure modification, Pipe 51 outfall and forebay to formalize regional detention and WQ. 12/17/09; plans & rpt.	10/5/2010
1315	Gateway Drive		<input checked="" type="checkbox"/> 8/20/1992	<input checked="" type="checkbox"/> 8/20/1992	<input checked="" type="checkbox"/> 2/6/1996	<input checked="" type="checkbox"/> 2/28/1997	11-6S-68W			One energy dissipator.	2/28/1997
726	Highlands Loop Culvert - Phase I		<input checked="" type="checkbox"/> 7/14/1981	<input type="checkbox"/> 7/14/1981	<input type="checkbox"/>	<input checked="" type="checkbox"/> 6/26/2007	10-6S-68W	825+00 830+00	Dad Clark Gulch FHAD	Phase II in 1991. See separate record. After the fact review and acceptance.	7/9/2007
1157	Highlands Ranch - S. Broadway Culv		<input checked="" type="checkbox"/> 3/27/1991	<input type="checkbox"/> 3/27/1991	<input type="checkbox"/>	<input checked="" type="checkbox"/> 6/26/2007	10-6S-68W	830+00 840+00	Dad Clark FHAD	AKA Highlands Loop Culvert Phase II. After the fact review and acceptance.	7/9/2007
963	Highlands Ranch (83-B)	Reach 6	<input checked="" type="checkbox"/> 7/29/1988	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	11-6S-68W			One storm sewer outfall proposed; x-ref MEFS 624...	8/25/1988
57	Highlands Ranch (Culvert 23)		<input checked="" type="checkbox"/> 2/7/1986	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> 9/7/2006	10-6S-68W			Burntwood Way & Culvert 23; project located u/s of FHAD study limits. 9/7/06; After-the-fact review and acceptance based on 7/20/06 site visit.	9/7/2006
1021	Highlands Ranch (Plan #103)		<input checked="" type="checkbox"/> 8/29/1989	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	10-6S-68W			Two storm sewer outlets only.	8/30/1989
624	Highlands Ranch (Plan #83)		<input checked="" type="checkbox"/> 7/7/1987	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> 6/26/2007	11-6S-68W			One storm sewer outfall. After the fact review and acceptance.	7/9/2007
2583	Highlands Ranch C-470/Plaza Drive		<input checked="" type="checkbox"/> 4/13/2000	<input checked="" type="checkbox"/> 9/7/2000	<input checked="" type="checkbox"/> 10/9/2002	<input type="checkbox"/> 6/2/2003	3-6S-68W			Reconfiguration of existing flood control and WQ facility. 7/4/00; const detail comments. 6/2/03; see repair list.	6/2/2003
1639	Highlands Ranch Culvert 27		<input checked="" type="checkbox"/> 9/11/1995	<input checked="" type="checkbox"/> 9/11/1995	<input checked="" type="checkbox"/> 4/30/1996	<input checked="" type="checkbox"/> 6/26/2007	10-6S-68W			One outlet structure. After the fact review and acceptance.	7/9/2007

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT	DESIGN	CNSTRCTN	ELIGIBLE	SEC TS R	STATIONING		STATION	COMMENTS	LAST UPDATE	
			OK? DATE	OK? DATE	OK? DATE	YES DATE		DS	US	REFERENCE			
1289	Highlands Ranch Culvert 31	Unnamed	<input checked="" type="checkbox"/> 11/10/1992	<input checked="" type="checkbox"/> 11/10/1992	<input checked="" type="checkbox"/> 11/17/2008	<input checked="" type="checkbox"/> 11/17/2008		10-6S-68W				Culvert, dissipator and channel with drops. 1/6/95; channel never completed, see letter this date. 9/7/06; repairs needed for final acceptance (see letter this date).	11/17/2008
3398	Highlands Ranch Filing 143, 1st Ame		<input checked="" type="checkbox"/> 5/12/2006	<input checked="" type="checkbox"/> 5/12/2006	<input checked="" type="checkbox"/> 7/23/2009	<input type="checkbox"/>		12-6S-68W				Two storm sewer outfalls. The WQ pond is excluded. See repair list dated 6/10/08.	7/23/2009
3322	Highlands Ranch Filing 150 Lot 1		<input checked="" type="checkbox"/> 6/15/2005	<input checked="" type="checkbox"/> 6/15/2005	<input checked="" type="checkbox"/> 11/17/2008	<input type="checkbox"/>		12-6S-68W				one storm sewer outfall 2/9/05; plans & rpt. 4/21/05; plans & rpt.	11/17/2008
2850	Highlands Ranch Filing 150 PA 64		<input checked="" type="checkbox"/> 3/5/2002	<input checked="" type="checkbox"/> 8/22/2003	<input type="checkbox"/>	<input type="checkbox"/>		12-6S-68W				one storm sewer outfall 3/5/02; plans & rpt. 11/13/02; plans & report. 2/27/03; plans & rpt. 5/30/03; plans & rpt.	8/22/2003
3397	Highlands Ranch Filing 150, Tresana		<input checked="" type="checkbox"/> 5/12/2006	<input checked="" type="checkbox"/> 5/12/2006	<input checked="" type="checkbox"/> 11/17/2008	<input type="checkbox"/>		12-6S-68W				Two pond outfalls. The WQ ponds are excluded.	11/17/2008
2389	Highlands Ranch Filing 20 Walgreens		<input checked="" type="checkbox"/> 1/15/1999	<input checked="" type="checkbox"/> 6/10/1999	<input checked="" type="checkbox"/> 2/9/2001	<input checked="" type="checkbox"/> 5/20/2004		10-6S-68W				1/15/99; need design calcs and plans. 4/5/99; one storm sewer outfall, revisions needed.	5/20/2004
725	Highlands Ranch Filing No. 1		<input checked="" type="checkbox"/> 9/15/1980	<input type="checkbox"/> 9/15/1980	<input type="checkbox"/>	<input type="checkbox"/> 7/11/2007		3-6S-68W	162+00	178+00	Dad Clark Gulch FHAD	Filed under Mission Viejo off site. Conditional acceptance. See repair list issued 7/11/07.	7/11/2007
1186	Highlands Ranch Filing No. 103-A		<input checked="" type="checkbox"/> 8/26/1991	<input checked="" type="checkbox"/> 8/26/1991	<input checked="" type="checkbox"/> 10/3/1994	<input checked="" type="checkbox"/> 6/28/1996		10-6S-68W	835+00	840+00	Dad Clark FHAD (Raub)	Storm sewer outlets (2) only.	6/28/1996
1253	Highlands Ranch Filing No. 103-B		<input checked="" type="checkbox"/> 9/9/1992	<input checked="" type="checkbox"/> 9/9/1992	<input checked="" type="checkbox"/> 9/27/1993	<input checked="" type="checkbox"/> 9/1/1998		10-6S-68W	840+00	842+00	Dad Clark FHAD	Dissipator only.	9/1/1998
1627	Highlands Ranch Filing No. 113-D		<input checked="" type="checkbox"/> 5/15/1995	<input checked="" type="checkbox"/> 5/15/1995	<input type="checkbox"/>	<input checked="" type="checkbox"/> 9/7/2006		10-6S-68W				Three storm sewer outlets. 9/7/06; After-the-fact review and acceptance based on 7/20/06 site visit.	9/7/2006
1512	Highlands Ranch Filing No. 119-A		<input checked="" type="checkbox"/> 6/20/1995	<input checked="" type="checkbox"/> 6/20/1995	<input checked="" type="checkbox"/> 10/7/1997	<input checked="" type="checkbox"/> 9/6/2006		14-6S-68W				One storm sewer outlet. See also ID # 1511	9/6/2006
2622	Highlands Ranch Filing No. 122-R		<input checked="" type="checkbox"/> 3/26/2001	<input checked="" type="checkbox"/> 3/26/2001	<input checked="" type="checkbox"/> 6/28/2006	<input checked="" type="checkbox"/> 6/26/2007		13,24-6S-68W				5 outfalls & open floodplain. After the fact review and acceptance.	7/9/2007
3108	Highlands Ranch Filing No. 122-Z		<input checked="" type="checkbox"/> 9/18/2002	<input checked="" type="checkbox"/> 9/18/2002	<input checked="" type="checkbox"/> 6/26/2006	<input checked="" type="checkbox"/> 6/26/2006		13-6S-68W				One storm sewer outfall.	6/26/2006
2156	Highlands Ranch Filing No. 2 Lot 6B		<input checked="" type="checkbox"/> 8/11/1997	<input checked="" type="checkbox"/> 8/11/1997	<input checked="" type="checkbox"/> 7/8/1999	<input checked="" type="checkbox"/> 8/20/2007		3-6S-68W				One storm sewer outlet. 6/24/97; Non-responsive to 5/7/97 comments.	8/20/2007
2089	Highlands Ranch Filing No. 2 Lot 6B		<input checked="" type="checkbox"/> 10/9/1996	<input type="checkbox"/> 10/9/1996	<input type="checkbox"/>	<input type="checkbox"/>						One storm sewer outlet.	10/9/1996

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT OK? DATE	DESIGN OK? DATE	CNSTRCTN OK? DATE	ELIGIBLE YES DATE	SEC TS R	STATIONING DS US	STATION REFERENCE	COMMENTS	LAST UPDATE
2621	Highlands Ranch Filing No. 20 Lots 1		<input checked="" type="checkbox"/> 6/8/2000	<input checked="" type="checkbox"/> 6/8/2000	<input checked="" type="checkbox"/> 12/2/2002	<input checked="" type="checkbox"/> 11/13/2003	9,10-6S-68W			Ridgeline Technology Center, reuse of impact basin.	11/13/2003
2651	Highlands Ranch Filing No. 20, Visa		<input checked="" type="checkbox"/> 9/7/2000	<input checked="" type="checkbox"/> 9/7/2000	<input checked="" type="checkbox"/> 12/2/2002	<input checked="" type="checkbox"/> 12/2/2002	3-6S-68W			8/3/00; Plans & report for single outfall, too high above drainageway invert.	12/2/2002
2512	Highlands Ranch Filing No. 20A Lot		<input checked="" type="checkbox"/> 11/2/1999	<input type="checkbox"/> 11/9/1999	<input type="checkbox"/>	<input type="checkbox"/> 6/26/2007	3-6S-68W			One storm sewer outfall. Conditional acceptance.	7/9/2007
2101	Highlands Ranch Filing No. 57A		<input checked="" type="checkbox"/> 11/26/1996	<input checked="" type="checkbox"/> 11/26/1996	<input type="checkbox"/>	<input type="checkbox"/>	3-6S-68W			One storm sewer outlet.	11/26/1996
1266	Highlands Ranch Filing No. 62-A	minor	<input checked="" type="checkbox"/> 12/11/1992	<input checked="" type="checkbox"/> 12/31/1992	<input checked="" type="checkbox"/> 12/3/1993	<input checked="" type="checkbox"/> 6/28/1996	10-6S-68W			One energy dissipator.	6/28/1996
1252	Highlands Ranch Filing No. 97-B	Reach 6	<input checked="" type="checkbox"/> 9/11/1992	<input checked="" type="checkbox"/> 9/11/1992	<input checked="" type="checkbox"/> 12/3/1993	<input checked="" type="checkbox"/> 6/28/1996	10-6S-68W			Outlet protection only.	6/28/1996
3422	Highlands Ranch Hyatt Classic Resid		<input checked="" type="checkbox"/> 7/25/2006	<input checked="" type="checkbox"/> 5/29/2007	<input checked="" type="checkbox"/> 5/28/2009	<input type="checkbox"/>	12-6S-68W			Classic Residence by Hyatt, two storm sewer outfalls. 7/25/06; plans & rpt. 11/12/06; plans & rpt. 1/25/07; plans & rpt. 5/2/07; plans.	5/28/2009
1398	Highlands Ranch PA70 Centennial Of		<input checked="" type="checkbox"/> 8/6/1984	<input checked="" type="checkbox"/> 8/6/1984	<input type="checkbox"/>	<input type="checkbox"/>	3-6S-68W	129+00	130+00	Dad Clark FHAD by Raub	10/12/1993
767	Highlands Ranch Pipe 31		<input type="checkbox"/> 6/26/1984	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3-6S-68W			tributary pipe energy disipator only.	10/12/1987
765	Highlands Ranch Pipe 31		<input checked="" type="checkbox"/> 8/23/1984	<input checked="" type="checkbox"/> 8/23/1984	<input type="checkbox"/>	<input checked="" type="checkbox"/> 9/7/2006	3-6S-68W			Tributary pipe energy disipator only. 9/7/06; After-the-fact review and acceptance based on 7/27/06 site visit.	9/7/2006
1305	Highlands Ranch Pipe 79	Unnamed	<input checked="" type="checkbox"/> 11/10/1992	<input checked="" type="checkbox"/> 11/10/1992	<input type="checkbox"/>	<input type="checkbox"/> 9/7/2006	10-6S-68W			9/7/06; repairs needed for final acceptance (see letter this date).	9/7/2006
1248	Highlands Ranch-Filing No. 97-A		<input type="checkbox"/> 3/11/1992	<input type="checkbox"/> 3/11/1992	<input type="checkbox"/>	<input checked="" type="checkbox"/> 9/7/2006	11-6S-68W			9/7/06; After-the-fact review and acceptance based on 7/20/06 site visit.	9/7/2006
1185	Highlands Ranch-Salford Lane	Unnamed	<input type="checkbox"/> 8/27/1991	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	10-6S-68W			Temp. outfall facility	8/26/1991
1247	Highlands Ranch-West Mansion Pkw		<input type="checkbox"/> 3/11/1992	<input type="checkbox"/> 3/11/1992	<input type="checkbox"/>	<input type="checkbox"/>	14-6S-68W				5/27/1992
1423	Kistler Drop		<input checked="" type="checkbox"/> 12/23/1993	<input type="checkbox"/> 12/23/1993	<input type="checkbox"/>	<input checked="" type="checkbox"/> 1/22/2008	10-6S-68W			Maint. Program may participate. Outfalls into Highline Canal. DCM participated in project.	1/22/2008
1281	The Bluffs	unnamed	<input checked="" type="checkbox"/> 9/8/1992	<input checked="" type="checkbox"/> 9/8/1992	<input checked="" type="checkbox"/> 12/3/1993	<input checked="" type="checkbox"/> 5/20/1996	3-6S-68W			Entrance road dissipator only.	5/20/1996
DAD CLARK GULCH - EAST TR											
3534	Dad Clark Gulch at Toepfer Park		<input checked="" type="checkbox"/> 9/18/2009	<input checked="" type="checkbox"/> 12/17/2009	<input checked="" type="checkbox"/> 5/25/2011	<input type="checkbox"/>	12-6S-68W			Trail crossing and drop structure.	5/25/2011

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT OK? DATE	DESIGN OK? DATE	CNSTRCTN OK? DATE	ELIGIBLE YES DATE	SEC TS R	STATIONING DS US	STATION REFERENCE	COMMENTS	LAST UPDATE
93	Highlands Ranch (64-A)	Reach 3	<input checked="" type="checkbox"/> 4/8/1986	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> 6/26/2007	2-6S-68W	518+50 519+00	Dad Clark Gulch FHAD	Outfall storm sewer w/impact basin. After the fact review and acceptance.	7/9/2007
641	Highlands Ranch (70-C)	Reach 3	<input type="checkbox"/> 7/30/1987	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	11-6S-68W	566+00 577+00	Dad Clark Gulch FHAD	Two storm sewer outfalls; fp fill questioned...	8/4/1987
961	Highlands Ranch (70-E)	Reach 3	<input checked="" type="checkbox"/> 8/2/1988	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> 6/26/2007	11-6S-68W	556+00 557+00	Dad Clark Gulch FHAD	One storm sewer outfall. After the fact review and acceptance.	7/9/2007
985	Highlands Ranch (79-C)	Reach 4	<input checked="" type="checkbox"/> 12/21/1988	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> 8/31/2006	11-6S-68W	607+00 608+00	Dad Clark Gulch FHAD	One storm sewer outfall; x-ref MEFS 623 & 962. 9/7/06; After-the-fact review and acceptance based on 7/27/06 site visit.	8/31/2006
913	Highlands Ranch (87-A)	Reach 3	<input checked="" type="checkbox"/> 2/1/1988	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> 6/26/2007	11-6S-68W	583+00 585+00	Dad Clark Gulch FHAD	One storm sewer outfall. After the fact review and acceptance.	7/9/2007
964	Highlands Ranch (87-B)	Reach 3	<input checked="" type="checkbox"/> 8/2/1988	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> 6/26/2007	11-6S-68W			Veneford Rd. x-ing. Conditional acceptance.	7/9/2007
983	Highlands Ranch (87-C)	Reach 3	<input checked="" type="checkbox"/> 12/16/1988	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> 6/26/2007	11,12,13-6S-68W			Two outfalls plus Veneford Ranch Rd. x-ing. Conditional acceptance.	7/9/2007
56	Highlands Ranch (Culvert 12)	Reach 3	<input checked="" type="checkbox"/> 2/11/1986	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> 9/6/2006	11-6S-68W	578+00 580+00	Dad Clark Gulch FHAD	North Highlands Ranch Pkwy & Culvert 12; final drainage report for N. Highlands Ranch Pkwy & Culvert 12 o.k. 9/6/06; After-the-fact review and acceptance.	9/6/2006
627	Highlands Ranch (Culvert 14)		<input checked="" type="checkbox"/> 7/10/1987	<input checked="" type="checkbox"/> 7/10/1987	<input type="checkbox"/>	<input type="checkbox"/>	12-6S-68W	338+50 344+50	Dad Clark Gulch FHAD		7/15/1987
1135	Highlands Ranch (Plan #114)		<input checked="" type="checkbox"/> 5/15/1991	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	13,14-6S-68W			Storm drain outlets only.	6/14/1991
1134	Highlands Ranch (Plan #116)		<input checked="" type="checkbox"/> 11/29/1990	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1,12-6S-68W			Storm drain outlets & undeveloped floodplain only.	12/12/1990
731	Highlands Ranch (Plan #2)	Reach 3	<input checked="" type="checkbox"/> 5/7/1981	<input checked="" type="checkbox"/> 5/7/1981	<input type="checkbox"/>	<input type="checkbox"/>	2,11-6S-68W	518+00 540+00	Dad Clark Gulch FHAD	Filed under Mission Viejo off site.	10/6/1987
720	Highlands Ranch (Plan #5)		<input checked="" type="checkbox"/> 1/4/1983	<input type="checkbox"/> 1/4/1983	<input type="checkbox"/>	<input type="checkbox"/>	1-6S-68W	265+50 288+00	Dad Clark Gulch FHAD	Filed under Mission Viejo off site.	10/6/1987
91	Highlands Ranch (Plan #64)	Reach 3	<input checked="" type="checkbox"/> 4/8/1986	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2-6S-68W	512+00 532+00	Dad Clark Gulch FHAD	Unimproved floodplain w/one outfall storm sewer impact basin...	6/10/1986
94	Highlands Ranch (Plan #64)	Reach 5	<input checked="" type="checkbox"/> 4/8/1986	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	11-6S-68W	733+00 740+00	Dad Clark Gulch FHAD	Outfall storm sewer w/impact basin...	6/10/1986
625	Highlands Ranch (Plan #84)		<input checked="" type="checkbox"/> 7/7/1987	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	12-6S-68W	291+50 292+50	Dad Clark Gulch FHAD	One storm sewer outfall...	7/8/1987
910	Highlands Ranch (Plan #87)	Reach 3	<input checked="" type="checkbox"/> 1/18/1988	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	11,12,13-6S-68W	583+00	Dad Clark Gulch FHAD	U/S Station above u/s FHAD study limit...	1/22/1988

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT		DESIGN		CNSTRCTN		ELIGIBLE		STATIONING		STATION REFERENCE	COMMENTS	LAST UPDATE		
			OK?	DATE	OK?	DATE	OK?	DATE	YES	DATE	SEC	TS R				DS	US
1022	Highlands Ranch (Plan #95)		<input checked="" type="checkbox"/>	8/24/1989	<input type="checkbox"/>		<input type="checkbox"/>					12,13-6S-68W		Two storm sewer outlets only.	8/30/1989		
369	Highlands Ranch 70-A	Reach 3	<input checked="" type="checkbox"/>	10/24/1986	<input type="checkbox"/>		<input type="checkbox"/>		<input checked="" type="checkbox"/>	9/6/2006		11-6S-68W	534+00	579+00	Dad Clark Gulch FHAD	o.k. to approve Sketch/Prelim w/minor revisions; fp encl. to be eliminated. 9/6/06; After-the-fact review and acceptance based on 8/31/06 site visit.	9/6/2006
768	Highlands Ranch Culvert 22		<input checked="" type="checkbox"/>	5/21/1985	<input type="checkbox"/>		<input type="checkbox"/>		<input checked="" type="checkbox"/>	9/6/2006		1-6S-68W	281+00	283+00	Dad Clark Gulch FHAD	9/6/06; After-the-fact review and acceptance.	9/6/2006
2371	Highlands Ranch Dad Clark Gulch	Middle & West Bran	<input checked="" type="checkbox"/>	4/7/2000	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>			13-6S-68W				Channel stabilization south of Pond 6, between Summit view Pkwy & Wildcat Reserve Pkwy, adj to Filings 122-F, I, J, & K. Need to review final plans	12/28/1999
761	Highlands Ranch Filing 15 -Planning		<input type="checkbox"/>	6/5/1984	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>	2/12/2008		2-6S-68W	247+00	253+00	Dad Clark Gulch FHAD	Two storm sewer outfalls. After the fact review. See repair list dated 2.12.08.	2/12/2008
727	Highlands Ranch Filing 4		<input checked="" type="checkbox"/>	4/24/1981	<input checked="" type="checkbox"/>	4/24/1981	<input type="checkbox"/>		<input checked="" type="checkbox"/>	9/6/2006		2,3-6S-68W	183+00	199+00	Dad Clark Gulch FHAD	Filed under Mission Viejo off site. 9/6/06; After-the-fact review and acceptance.	9/6/2006
728	Highlands Ranch Filing 4	Reach 5	<input checked="" type="checkbox"/>	4/24/1981	<input checked="" type="checkbox"/>	4/24/1981	<input type="checkbox"/>		<input checked="" type="checkbox"/>	9/6/2006		3-6S-68W	709+00	720+00	Dad Clark Gulch FHAD	Filed under Mission Viejo off site. 9/6/06; After-the-fact review and acceptance.	9/6/2006
721	Highlands Ranch Filing 5		<input checked="" type="checkbox"/>	1/4/1983	<input checked="" type="checkbox"/>	1/4/1983	<input type="checkbox"/>		<input checked="" type="checkbox"/>	9/6/2006		2-6S-66W	199+00	217+00	Dad Clark FHAD	Filed under Mission Viejo off site. 9/6/06; After-the-fact review and acceptance.	9/6/2006
729	Highlands Ranch Filing 5	Reach 5	<input checked="" type="checkbox"/>	6/10/1981	<input checked="" type="checkbox"/>	6/10/1981	<input type="checkbox"/>		<input checked="" type="checkbox"/>	9/6/2006		3-6S-68W	720+00	730+00	Dad Clark Gulch FHAD	Filed under Mission Viejo off site. 9/6/06; After-the-fact review and acceptance.	9/6/2006
722	Highlands Ranch Filing 5	Reach 3	<input checked="" type="checkbox"/>	1/4/1983	<input checked="" type="checkbox"/>	1/4/1983	<input type="checkbox"/>		<input checked="" type="checkbox"/>	9/6/2006		3-6S-68W	500+00	510+00	Dad Clark Gulch FHAD	9/6/06; After-the-fact review and acceptance.	9/6/2006
1180	Highlands Ranch Filing 84-E		<input checked="" type="checkbox"/>	8/1/1991	<input checked="" type="checkbox"/>	8/1/1991	<input checked="" type="checkbox"/>	11/23/1993	<input checked="" type="checkbox"/>	6/28/2006		12-6S-68W	292+00	293+00		One storm sewer outlet only. Reveg. still a problem.	6/28/2006
1009	Highlands Ranch Filing 91-A	Reach 4	<input checked="" type="checkbox"/>	6/12/1989	<input checked="" type="checkbox"/>	6/12/1989	<input checked="" type="checkbox"/>	11/15/1989	<input checked="" type="checkbox"/>	11/24/1993		11-6S-68W			Dad Clark Gulch FHAD	Storm sewer outfall only.	7/9/2007
1008	Highlands Ranch Filing 91-A	Reach 3	<input checked="" type="checkbox"/>	6/12/1989	<input checked="" type="checkbox"/>	6/12/1989	<input checked="" type="checkbox"/>	11/15/1989	<input checked="" type="checkbox"/>	11/24/1993		11-6S-68W			Dad Clark Gulch FHAD	Storm sewer outfalls only.	11/24/1993
1069	Highlands Ranch Filing 94-B		<input type="checkbox"/>	9/12/1991	<input type="checkbox"/>		<input type="checkbox"/>		<input checked="" type="checkbox"/>	9/6/2006		12-6S-68W				Outlet dissipators only. 9/6/06; After-the-fact review and acceptance.	9/6/2006

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT OK? DATE	DESIGN OK? DATE	CNSTRCTN OK? DATE	ELIGIBLE YES DATE	SEC TS R	STATIONING DS US	STATION REFERENCE	COMMENTS	LAST UPDATE
1211	Highlands Ranch Filing 95 Pipe 85		<input checked="" type="checkbox"/> 10/30/1991	<input checked="" type="checkbox"/> 10/30/1991	<input type="checkbox"/> 3/5/1993	<input checked="" type="checkbox"/> 6/26/2007	12-6S-68W			Pipe 85. After the fact review and acceptance.	7/9/2007
1061	Highlands Ranch Filing 96-A		<input checked="" type="checkbox"/> 3/8/1990	<input checked="" type="checkbox"/> 4/26/1990	<input checked="" type="checkbox"/> 11/23/1993	<input checked="" type="checkbox"/> 6/28/2006	1-6S-68W			One storm sewer outlet only.	6/28/2006
2145	Highlands Ranch Filing No. 122-D		<input checked="" type="checkbox"/> 3/26/1997	<input checked="" type="checkbox"/> 11/6/1997	<input checked="" type="checkbox"/> 6/30/2000	<input checked="" type="checkbox"/> 4/2/2003	12-6S-68W			Three storm sewer outlets.	4/2/2003
2167	Highlands Ranch Filing No. 122-E		<input checked="" type="checkbox"/> 10/21/1997	<input checked="" type="checkbox"/> 12/8/1997	<input checked="" type="checkbox"/> 3/6/2001	<input checked="" type="checkbox"/> 9/6/2006	12,13-6S-68W			Three storm sewer outlets.	9/6/2006
2252	Highlands Ranch Filing No. 122-I		<input checked="" type="checkbox"/> 5/7/1998	<input checked="" type="checkbox"/> 5/7/1998	<input checked="" type="checkbox"/> 4/4/2001	<input checked="" type="checkbox"/> 10/14/2004	13-6S-68W			Four storm sewer outfalls.	10/14/2004
2285	Highlands Ranch Filing No. 122-K		<input checked="" type="checkbox"/> 6/24/1998	<input checked="" type="checkbox"/> 6/24/1998	<input checked="" type="checkbox"/> 10/15/2004	<input checked="" type="checkbox"/> 10/15/2004	13-6S-68W			Four storm sewer outlets. Drainageway eligibility is subject to stability report and channel plan & profile design	10/15/2004
2519	Highlands Ranch Filing No. 122-M		<input checked="" type="checkbox"/> 3/10/2000	<input checked="" type="checkbox"/> 3/10/2000	<input checked="" type="checkbox"/> 11/13/2000	<input checked="" type="checkbox"/> 9/9/2004	13-6S-68W			one outfall, 84-inch w/drop	9/9/2004
3375	Highlands Ranch Filing No. 150, 2nd		<input type="checkbox"/> 11/1/2005	<input type="checkbox"/> 1/20/2006	<input type="checkbox"/>	<input type="checkbox"/>	12-6S-68W	298+00 341+00	Dad Clark Gulch FHAD	Tresanna II Townhomes, 11/1/05: Actually 3rd submittal, filed under HR Hyatt. Gulch ownership and Maint. In doubt. 1/20/06; const plans & rpt.	1/31/2006
2140	Highlands Ranch Filing No. 52-E & 5		<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> 3/17/1997	<input checked="" type="checkbox"/> 3/17/1997	2-6S-68W			Can't find paperwork on these but Merrick had recommended acceptance of const. and Frank R. has recommended acceptance of vegetation.	3/17/1997
1194	Highlands Ranch Filing No. 94-D	Reach 1	<input checked="" type="checkbox"/> 9/27/1991	<input checked="" type="checkbox"/> 9/27/1991	<input checked="" type="checkbox"/> 6/28/2006	<input checked="" type="checkbox"/> 6/28/2006	12-6S-68W	320+00 340+00	Dad Clark FHAD	Two outlet structures only.	6/28/2006
1519	Highlands Ranch Filing No. 95-A		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> 3/17/1997	<input checked="" type="checkbox"/> 3/17/1997	12-6S-68W			Can't find paperwork on this one.	3/17/1997
2178	Highlands Ranch Pond 5	1	<input checked="" type="checkbox"/> 7/16/1997	<input checked="" type="checkbox"/> 9/14/1998	<input checked="" type="checkbox"/> 5/12/1999	<input type="checkbox"/> 9/7/2006	13-6S-68W		Dad Clark Gulch MP (Raub)	Part of Summit View Parkway. Pond, dissipater and 1 storm sewer outlet. See also records 2179 & 2328. 9/7/06; repairs needed for final acceptance (see letter this date).	9/7/2006
2179	Highlands Ranch Pond 6	2	<input checked="" type="checkbox"/> 7/16/1997	<input checked="" type="checkbox"/> 9/14/1998	<input checked="" type="checkbox"/> 5/12/1999	<input type="checkbox"/> 9/7/2006	13-6S-68W		Dad Clark Gulch MP (Raub)	Part of Summit View Parkway. Pond, dissipater and 1 storm sewer outlet. See also records 2178 & 2328. 9/7/06; repairs needed for final acceptance (see letter this date).	9/7/2006
1209	Highlands Ranch Prelim. Plan 114	Reach 4	<input checked="" type="checkbox"/> 11/8/1991	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	14-6S-68W				11/11/1991
2215	Highlands Ranch Wildcat Reserve Par		<input checked="" type="checkbox"/> 8/12/1998	<input checked="" type="checkbox"/> 8/12/1998	<input checked="" type="checkbox"/> 4/4/2001	<input checked="" type="checkbox"/> 7/30/2007	13-6S-68W			Three road crossings w/channelization u/s & d/s and energy dissipaters. Pipes not eligible. See also 2214.	7/30/2007

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT		DESIGN		CNSTRCTN		ELIGIBLE		STATIONING		STATION REFERENCE	COMMENTS	LAST UPDATE
			OK?	DATE	OK?	DATE	OK?	DATE	YES	DATE	SEC	TS R			
2328	Summit View Parkway 1997 Phase V	1 & 2	<input checked="" type="checkbox"/>	7/16/1998	<input checked="" type="checkbox"/>	9/14/1998	<input checked="" type="checkbox"/>	5/12/1999	<input type="checkbox"/>	9/7/2006		13-6S-68W		Regional detention ponds 5 & 6, Pipes P-45 & P-TCB1. See also records 2178 & 2179. 9/7/06; repairs needed for final acceptance (see letter this date).	9/7/2006
EAST PLUM CREEK															
2446	Waverton Ranch	un-named	<input checked="" type="checkbox"/>	7/5/1999	<input type="checkbox"/>	7/5/1999	<input type="checkbox"/>		<input type="checkbox"/>			30-7S-67W		open floodpain	7/6/1999
FONDER DRAW															
1493	High Prairie Farms at The Pinery		<input type="checkbox"/>	6/14/1994	<input type="checkbox"/>	6/14/1994	<input type="checkbox"/>		<input type="checkbox"/>			14-7S-66W		Two storm sewer outlets.	6/14/1994
1409	Pinery NW		<input type="checkbox"/>	8/29/1995	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>			10-7S-66W		Rezone and sketch plan.	8/29/1995
3445	Pinery West		<input checked="" type="checkbox"/>	5/1/2007	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>			10-7S-66W	0+00 21+80'	Kinney/Fonder FHAD 5/1/07: Sketch Plan #2. FP preservation. 2/16/09: Preliminary plan.	5/1/2007
3533	Pinery West Filing 1		<input type="checkbox"/>	7/22/2009	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>			10-7S-66W		Kinney/Fonder FHAD improvements	2/15/2010
HAPPY CANYON CREEK															
1590	Castle Pines North	Glenridge	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>			4-7S-67W	0+00 25+00	Happy Canyon OSP Approved by Dougco before annexation by UDFCD. For info only.	3/28/1995
1588	Castle Pines North	Monarch	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>			32,33-6S-67W	17+25 47+50	Happy Canyon OSP Approved by Dougco before annexation by UDFCD. For info only.	3/28/1995
1587	Castle Pines North		<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>			4,9-7S-67W	578+00 637+00	Happy Canyon OSP Approved by Dougco before annexation by UDFCD. For info only.	3/28/1995
1589	Castle Pines North	Oak Hills	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>			32,33-6S-67W	109+00 139+50	Happy Canyon OSP Approved by Dougco before annexation by UDFCD. For info only.	3/28/1995
2147	Castle Pines North Filing No. 16	Monarch	<input checked="" type="checkbox"/>	6/28/1999	<input checked="" type="checkbox"/>	6/28/1999	<input checked="" type="checkbox"/>	2/12/2008	<input checked="" type="checkbox"/>	2/12/2008		33-6S-67W	18+00 32+00	Happy Canyon OSP Detention pond, 3 storm sewer inlets, drop structure. 5/9/97: Final plat. 6/23/98: generally non-responsive to 4/1/97 comments. 4/5/99: geotechnical and water quality issues unresolved.	2/12/2008
2007	Castle Pines North Filing No. 17-A		<input checked="" type="checkbox"/>	10/27/1995	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>			4-7S-67W	578+00 588+00	Happy Canyon OSP Existing detention pond and drop structures pre-date annexation by UDFCD. Need to monitor.	10/27/1995
2024	Castle Pines North Filing No. 18	Glenridge	<input type="checkbox"/>	12/12/1995	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>			4-7S-67W	3+00 10+00	Happy Canyon OSP Trib. apparently in open space but need more info to be sure.	12/12/1995

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT OK? DATE	DESIGN OK? DATE	CNSTRCTN OK? DATE	ELIGIBLE YES DATE	SEC TS R	STATIONING DS US	STATION REFERENCE	COMMENTS	LAST UPDATE	
2466	Castle Pines North Filing No. 27	Oak Hills	<input checked="" type="checkbox"/> 11/5/1999	<input type="checkbox"/> 11/5/1999	<input type="checkbox"/>	<input type="checkbox"/>	5,32,33-6S-67W			Appears to be open flood plain, need to see a drainage study. 11/5/99: needs grade controls and resolution of detention status.	11/5/1999	
3557	Chambers Reservoir	Stonegate	<input type="checkbox"/> 8/3/2010	<input checked="" type="checkbox"/> 8/31/2010	<input type="checkbox"/>	<input type="checkbox"/>	5,8-6S-66W		Happy Canyon OSP	Reservoir and det pond outfall.	8/31/2010	
3019	Compark 190	Stonegate	<input type="checkbox"/> 2/8/2002	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5-6S-66W	0+00	5+50	Happy Canyon OSP	02/08/02: Rezoning.	8/20/2002
3018	Compark 190	Green Acres	<input type="checkbox"/> 8/20/2002	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	6-6S-66W	97+00	116+00	Happy Canyon OSP	8/20/02: Rezoning.	8/20/2002
3017	Compark 190		<input type="checkbox"/> 8/20/2002	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	6-6S-66W	106+00	124+00	Happy Canyon OSP	8/20/02: Rezoning.	8/20/2002
2164	Compark 470	E-470	<input checked="" type="checkbox"/> 5/30/1997	<input type="checkbox"/> 3/18/1999	<input type="checkbox"/>	<input type="checkbox"/>	6-6S-66W	0+00	6+00	Happy Canyon OSP	See also 2163 & 2165. 5/30/97: rezoning. 3/18/99: preliminary plan, concept still ok.	3/22/1999
3381	Compark American Furniture Wareho	Green Acres Tributary	<input type="checkbox"/> 1/19/2000	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> 1/20/2006	6-6S-66W				1/19/2000: SIP. One storm sewer outfall after-the-fact.	1/20/2006
2974	Compark Filing No. 5	Green Acres	<input checked="" type="checkbox"/> 1/23/2002	<input type="checkbox"/> 1/23/2002	<input type="checkbox"/>	<input type="checkbox"/>	6-6S-66W				See also 2975. One detention pond outfall to Green Acres Tributary.	4/24/2002
2975	Compark Filing No. 5		<input checked="" type="checkbox"/> 1/23/2002	<input type="checkbox"/> 1/23/2002	<input type="checkbox"/>	<input type="checkbox"/>	6-6S-66W				See also 2974. One detention pond outfall to Happy Canyon Creek.	4/24/2002
2829	Compark Green Acres Tributary Phas	Green Acres	<input checked="" type="checkbox"/> 5/30/1997	<input checked="" type="checkbox"/> 8/20/2003	<input checked="" type="checkbox"/> 2/20/2004	<input checked="" type="checkbox"/> 5/25/2005	5,6-6S-66W				See also 2164 & 2165. 5/30/97: rezoning. 3/18/99: preliminary plan, concept still ok. 9/12/01; Plans & rpt, Phase II will add new road crossing at Clocktower Cir. Orig approval has expired.	5/25/2005
2163	Compark Green Acres Tributary Phas	Green Acres	<input checked="" type="checkbox"/> 5/30/1997	<input checked="" type="checkbox"/> 8/11/1999	<input checked="" type="checkbox"/> 12/2/2002	<input checked="" type="checkbox"/> 5/25/2005	5,6-6S-66W	25+00	97+00	Happy Canyon OSP	See also 2164 & 2165. 5/30/97: rezoning. 3/18/99: preliminary plan, concept still ok.	5/25/2005
2165	Compark Happy Canyon Creek		<input checked="" type="checkbox"/> 3/18/1999	<input checked="" type="checkbox"/> 4/21/2000	<input checked="" type="checkbox"/> 12/2/2002	<input checked="" type="checkbox"/> 5/5/2004	5-6S-66W	49+50	134+00	Happy Canyon OSP	See also 2543, 2163 & 2164. 5/30/97: rezoning. 3/18/99: preliminary plan, concept still ok. 11/10/99; numerous comments on riprap & grade controls. 3/2/00; design comments.	5/5/2004
2543	Compark Happy Canyon Creek Bridg		<input checked="" type="checkbox"/> 1/27/2000	<input checked="" type="checkbox"/> 3/15/2000	<input checked="" type="checkbox"/> 12/2/2002	<input checked="" type="checkbox"/> 5/5/2004	5-6S-66W				Chambers Road bridge & drop structure, see also 2165. 1/27/00; minor revisions & 404 permit coordination.	5/5/2004
711	Cottonwood Industrial Park		<input type="checkbox"/> 5/27/1981	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5-6S-66W	80+00	105+50	Happy Canyon FHAD		10/5/1987

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT	DESIGN	CNSTRCTN	ELIGIBLE	SEC TS R	STATIONING		STATION	COMMENTS	LAST UPDATE
			OK? DATE	OK? DATE	OK? DATE	YES DATE		DS	US	REFERENCE		
1362	Green Valley	Oak Hills Trib.	<input checked="" type="checkbox"/> 10/8/1993	<input checked="" type="checkbox"/> 8/15/1995	<input checked="" type="checkbox"/> 9/3/1997	<input checked="" type="checkbox"/> 10/30/2002	33-6S-67W			Happy Canyon Creek Watershed OSP	Two storm sewer outlets and open FP. Formerly Hidden Pointe. 4/23/97: Boyle says many problems exist.	10/30/2002
1363	Green Valley	Monarch Trib.	<input checked="" type="checkbox"/> 10/8/1993	<input checked="" type="checkbox"/> 8/15/1995	<input checked="" type="checkbox"/> 9/3/1997	<input checked="" type="checkbox"/> 10/30/2002	33-6S-67W	0+00	7+00	Happy Canyon Creek Watershed OSP Phase A	Channel and drops Formerly. Hidden Pointe.	10/30/2002
2231	Green Valley Filing 1-B	Monarch Trib.	<input checked="" type="checkbox"/> 1/19/1998	<input checked="" type="checkbox"/> 2/2/1999	<input checked="" type="checkbox"/> 10/30/2002	<input checked="" type="checkbox"/> 10/30/2002	33-6S-67W	7+00	15+00	Happy Canyon Creek Watershed OSP	1/20/98 - Phase I drainage study. 10/12/98: very incomplete submittal, did not address 1/20/98 comments. 12/8/98: maintenance access & minor revisions.	10/30/2002
691	Hope 480		<input type="checkbox"/> 4/2/1982	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	6-6S-66W	105+50	133+50	Happy Canyon FHAD		10/5/1987
692	Hope 480		<input type="checkbox"/> 4/2/1982	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5-6S-66W	50+00	80+00	Happy Canyon FHAD		10/5/1987
693	Hope 480	unnamed	<input type="checkbox"/> 4/2/1982	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5,6-6S-66W					10/5/1987
674	Jordan Ranch	unnamed	<input type="checkbox"/> 10/14/1982	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	6-6S-66W				Two unnamed tribs. Not considered in plan.	10/2/1987
2299	Lynx Land (Castle Pines North #27)	Oak Hills	<input type="checkbox"/> 7/7/1999	<input type="checkbox"/> 11/5/1999	<input type="checkbox"/>	<input type="checkbox"/>	32,33-6S-67W	109+00	139+50	Happy Canyon OSP	7/27/98: Concept plan not approved. 11/4/98: Preliminary plan not approved. 11/18/98: Previous comments reiterated to PW. 7/7/99: Final drainage report probs. 11/5/99; needs grade control structures.	11/5/1999
3355	Meridian Int Bus Center SP 7A	Grandview	<input type="checkbox"/> 7/11/2005	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	18-6S-66W	79+00	94+00	Happy Canyon OSP	7/11/05: Sketch plan ignores drainageway.	7/11/2005
2601	Meridian Internat'l Business Ctr Flg 5		<input checked="" type="checkbox"/> 10/2/2002	<input checked="" type="checkbox"/> 11/27/2002	<input checked="" type="checkbox"/> 6/12/2006	<input checked="" type="checkbox"/> 10/2/2006	13,14-6S-67W	257+00	285+00	Happy Canyon OSP	5/26/00: Final plat. Several deficiencies. 10/20/00; open floodway, 3 outfalls, concept problems. 4/16/01; const plans need coop w/adj prop on grade controls. 11/8/01; same problems. 10/2/02: plan	10/2/2006
2455	Meridian Internat'l Business Ctr Flg 7		<input checked="" type="checkbox"/> 7/9/1999	<input type="checkbox"/> 8/22/2000	<input type="checkbox"/>	<input type="checkbox"/>	13-6S-67W	255+00	285+00	Happy Canyon OSP	7/9/99: Adding property to PD. Say they will stay out of floodplain. 6/29/00; study & plans, very preliminary. 8/22/00; phase 2 study should address road crossing.	8/28/2000
2229	Meridian Office Park Filing No. 4	Green Acres	<input type="checkbox"/> 9/28/1998	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	12-6S-67W	155+00	191+00	Happy Canyon OSP	12/8/97 plat	9/28/1998
3249	Meridian Villages		<input type="checkbox"/> 8/16/2004	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	18-6S-66W	201+00	212+00	Happy Canyon FHAD	8/16/04: plat.	8/25/2004

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT		DESIGN		CNSTRCTN		ELIGIBLE		STATIONING		STATION REFERENCE	COMMENTS	LAST UPDATE	
			OK?	DATE	OK?	DATE	OK?	DATE	YES	DATE	SEC	TS R				DS
3012	Oak Hills Trib Weir & Coyote Ridge	Oak Hills Trib.	<input checked="" type="checkbox"/>	7/17/2002	<input checked="" type="checkbox"/>	7/17/2002	<input checked="" type="checkbox"/>	11/6/2007	<input checked="" type="checkbox"/>	11/6/2007				Coyote Ridge Park & Flow Measuring Weir. 3/11/02; 2 sts plans & rpts. 6/26/02; minor comments on Jehn & Meurer docs.	11/6/2007	
334	Rampart Range		<input checked="" type="checkbox"/>	10/2/1984	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>				13,14,22-6S-67W; 23-6S-67W	212+00 425+00 Happy Canyon Creek FHAD	9/3/1986	
3268	Sierra Ridge F 1	Grandview	<input checked="" type="checkbox"/>	2/15/2007	<input checked="" type="checkbox"/>	6/30/2008	<input type="checkbox"/>		<input type="checkbox"/>				18-6S-66W	32+00 96+00 Happy Canyon OSP	10/11/04: Rezoning. 12/12/05: Sketch plan (formerly Lincoln/Chambers). 8/23/06; plans & rpt. 2/15/07, 9/5/07, 2/8/08, 3/31/08; plans & rpt. 8/21/08; Isle St. culvert now included in Flg 1 plans.	8/21/2008
3269	Sierra Ridge F 1	Stonegate	<input checked="" type="checkbox"/>	2/15/2007	<input checked="" type="checkbox"/>	7/1/2010	<input type="checkbox"/>		<input type="checkbox"/>				18-6S-66W	70+00 77+30 Happy Canyon OSP	10/11/04: Rezoning. 12/12/05: Sketch plan (formerly Lincoln/Chambers). 8/23/2006; plans & rpt. 2/15/07; plans & rpt. 9/5/07; plans & rpt. 2/8/08; plans & rpt. 3/31/08; plans & rpt. Apr 6-30-08	7/1/2010
328	Southeast Center	un-named	<input type="checkbox"/>	6/2/1983	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>				5,6-6S-66W		9/3/1986	
331	Southeast Center		<input type="checkbox"/>	6/2/1983	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>				5,6-6S-66W	50+00 133+50 Happy Canyon Creek FHAD	9/3/1986	
223	Stonegate #3	un-named (C1)	<input checked="" type="checkbox"/>	5/10/1985	<input type="checkbox"/>	7/29/1985	<input type="checkbox"/>		<input type="checkbox"/>				8-6S-66W		Master Drainage Plan approved; problems w/Final Drainage Study...	6/11/1986
2180	Stonegate Chambers Road	Stonegate	<input checked="" type="checkbox"/>	9/29/1997	<input checked="" type="checkbox"/>	9/29/1997	<input checked="" type="checkbox"/>	7/8/1999	<input checked="" type="checkbox"/>	2/12/2008			8-6S-66W	60+00 61+00 Happy Canyon OSP	Two storm sewer outlets.	2/12/2008
1340	Stonegate Filing 3-C	Unnamed	<input type="checkbox"/>	5/3/1993	<input type="checkbox"/>		<input type="checkbox"/>		<input checked="" type="checkbox"/>	2/12/2008			17-6S-66W		One storm sewer outfall. After the fact review and acceptance.	2/12/2008
2807	Stonegate Tributary Stabilization	Stonegate Tributary	<input checked="" type="checkbox"/>	8/6/2001	<input checked="" type="checkbox"/>	2/27/2003	<input checked="" type="checkbox"/>	2/12/2008	<input type="checkbox"/>	2/12/2008			8-6S-66W	9+00 67+00 Happy Canyon OSP	8/6/01: Prelim. Design. 2/21/01; const plans 7/16/02; const plans. 11/13/02; plans & rpt. 2/12/08 repair list.	2/12/2008
2494	Stonegate Village Arterial Roads	Stonegate	<input checked="" type="checkbox"/>	2/11/2000	<input checked="" type="checkbox"/>	5/23/2000	<input type="checkbox"/>		<input type="checkbox"/>				8-6S-66W		See also 2495 & 2626, two storm sewer outfalls. 2/11/00: minor comments.	5/23/2000
2626	Stonegate Village Arterial Roads Ph II	Stonegate	<input checked="" type="checkbox"/>	7/4/2000	<input checked="" type="checkbox"/>	11/21/2000	<input type="checkbox"/>		<input type="checkbox"/>				8-6S-66W		See also 2494 & 2495, one storm sewer outfall. 7/4/00: report & plans, minor comments.	11/21/2000

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT OK? DATE	DESIGN OK? DATE	CNSTRCTN OK? DATE	ELIGIBLE YES DATE	SEC TS R	STATIONING DS US	STATION REFERENCE	COMMENTS	LAST UPDATE	
HASKIN GULCH												
2022	Castle Pines Village Filing No. 20		<input type="checkbox"/> 11/20/1995	<input type="checkbox"/> 2/5/1998	<input type="checkbox"/>	<input type="checkbox"/> 1/22/2008	15,16-7S-67W			Need to define floodplain and address ownership. Not eligible-private owner.	1/22/2008	
KINNEY CREEK												
2660	Reata South		<input checked="" type="checkbox"/> 7/25/2000	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1,2,3-7S-66W			7/25/00: Zoning.	8/17/2000	
3306	Reata South Golf Course	B	<input type="checkbox"/> 6/23/2005	<input type="checkbox"/> 6/23/2005	<input type="checkbox"/>	<input type="checkbox"/>	2-7S-66W	0+00	26+50	Kinney, Fonder FHAD	1/3/05: SIP. 3/2/05; Final Draiang and GESC rpt. 6/23/05; plans & rpt.	6/23/2005
3304	Reata South Golf Course		<input type="checkbox"/> 6/23/2005	<input type="checkbox"/> 6/23/2005	<input type="checkbox"/>	<input type="checkbox"/>	2-7S-66W	77+00	128+50	Kinney, Fonder FHAD	1/3/05: SIP. 3/2/05; Final Draiang and GESC rpt. 6/23/05; plans & rpt.	6/23/2005
3305	Reata South Golf Course	A	<input type="checkbox"/> 6/23/2005	<input type="checkbox"/> 6/23/2005	<input type="checkbox"/>	<input type="checkbox"/>	2-7S-66W	13+00	20+00	Kinney, Fonder FHAD	1/3/05: SIP. 3/2/05; Final Draiang and GESC rpt. 6/23/05; plans & rpt.	6/23/2005
LEE GULCH												
733	Highlands Ranch (Plan #13)		<input type="checkbox"/> 4/30/1984	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2-6S-68W	227+00	230+65	Lee Gulch FHAD		10/6/1987
278	Highlands Ranch (Plan #65)		<input type="checkbox"/> 7/7/1986	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2-6S-68W	219+00	230+65	Lee Gulch FHAD	Elimination of floodplain questioned; C-470 plans not approved by District...	7/9/1986
766	Highlands Ranch Filing 25		<input checked="" type="checkbox"/> 9/20/1984	<input type="checkbox"/> 9/20/1984	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-6S-68W	219+50	222+50	Lee Gulch FHAD		10/12/1987
LEMON GULCH												
2085	Denver Brick Co. Stevens Clay Lease	Unnamed	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	8-7S-66W			9/24/96: Requested drainage info.	9/24/1996	
LITTLE WILLOW CREEK												
606	Castle Rox		<input checked="" type="checkbox"/> 3/24/1987	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-7S-69W			u/s of Rampart Range Rd.; PUD and zoning o.k...	3/24/1987	
2310	Chatfield Farms Filing 1-A		<input checked="" type="checkbox"/> 10/9/2001	<input checked="" type="checkbox"/> 10/2/2002	<input checked="" type="checkbox"/> 7/20/2007	<input checked="" type="checkbox"/> 7/20/2007	35-6S-69W	35+00	59+00	Willow Creek FHAD	Two storm sewer outfalls.	7/20/2007
3196	Chatfield Farms Filing 1-B		<input checked="" type="checkbox"/> 6/24/2004	<input checked="" type="checkbox"/> 6/24/2004	<input checked="" type="checkbox"/> 7/20/2007	<input checked="" type="checkbox"/> 7/20/2007	35-6S-69W	35+00	59+00	Willow Creek FHAD	Channel stabilization and two storm sewer outfalls.	7/20/2007
3238	Chatfield Farms Filing 1-B, Waterton		<input checked="" type="checkbox"/> 6/30/2004	<input checked="" type="checkbox"/> 8/19/2004	<input checked="" type="checkbox"/> 7/20/2007	<input checked="" type="checkbox"/> 7/20/2007	35-6S-69W	30+00	35+00	Willow Creek FHAD	Culvert and energy dissipator.	7/20/2007
3498	Douglas County Elementary School 4		<input checked="" type="checkbox"/> 8/7/2008	<input checked="" type="checkbox"/> 8/7/2008	<input type="checkbox"/>	<input type="checkbox"/>	1-7S-69W			Roxborough (DV 06 293), one storm sewer outfall.	8/7/2008	
217	Rampart Range Rd.		<input type="checkbox"/> 7/29/1985	<input type="checkbox"/> 7/29/1985	<input type="checkbox"/>	<input type="checkbox"/> 12/9/1985	1,2-7S-69W			x-ref: Roxborough Villages; culvert ext. by Rox Metro Dist; existing culvert @ 5% slope; grade change w/riprap @ outlet does not comply w/USDCM	6/11/1986	

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT		DESIGN		CNSTRCTN		ELIGIBLE		STATIONING		STATION REFERENCE	COMMENTS	LAST UPDATE	
			OK?	DATE	OK?	DATE	OK?	DATE	YES	DATE	SEC	TS R				DS
2860	Roxborough Park Filing No. 4		<input type="checkbox"/>	12/10/2001	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>		12-7S-69W	174+00	180+00	Willow et. al. FHAD	12/10/01: final plat.	12/10/2001
3499	Roxborough Park Flg 1, Grand View		<input checked="" type="checkbox"/>	8/7/2008	<input checked="" type="checkbox"/>	8/7/2008	<input type="checkbox"/>		<input type="checkbox"/>		12-7S-69W				Two storm sewer outfalls.	8/7/2008
1065	Roxborough Village		<input type="checkbox"/>	5/9/1990	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>		2-7S-69W				Irrigation ponds within stormwater detention pond. Lots of problems.	5/11/1990
544	Roxborough Village (Parcel C)		<input checked="" type="checkbox"/>	12/30/1986	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>		35-6S-69W				Also known as Filing 9; located along left bank d/s of Village Circle West; 3 storm sewer outfalls...	12/31/1986
59	Roxborough Village (Parcel H)		<input checked="" type="checkbox"/>	3/1/1985	<input type="checkbox"/>	2/7/1986	<input type="checkbox"/>		<input type="checkbox"/>		2-7S-69W				Problems with storm sewer outfalls...	6/10/1986
54	Roxborough Village (Parcel I)		<input checked="" type="checkbox"/>	3/1/1985	<input type="checkbox"/>	1/6/1987	<input type="checkbox"/>		<input type="checkbox"/>		2-7S-69W				Storm sewer outfalls; includes Phases 1 and 2....	1/9/1987
547	Roxborough Village (Parcels A&B)		<input checked="" type="checkbox"/>	1/6/1987	<input type="checkbox"/>	1/6/1987	<input type="checkbox"/>		<input type="checkbox"/>		35-6S-69W				Phase 2 only; also known as Executive Homes; storm sewer outfall channels questioned...	1/9/1987
2069	Roxborough Village Filing 14 Phase		<input checked="" type="checkbox"/>	7/9/1997	<input checked="" type="checkbox"/>	7/9/1997	<input checked="" type="checkbox"/>	3/30/1998	<input checked="" type="checkbox"/>	5/8/2003	2-7S-69W				7/23/96: Two storm sewer outlets, trail is asphalt and not eligible, open space floodplain. 2/23/01; repairs needed, see memo this date. 5/14/02; new repair list.	5/8/2003
2021	Roxborough Village Filing 14, Phase		<input checked="" type="checkbox"/>	7/9/1997	<input checked="" type="checkbox"/>	7/9/1997	<input checked="" type="checkbox"/>	2/23/2001	<input checked="" type="checkbox"/>	5/8/2003	2-7S-69W				(11/20/95) Relies on channel design from 1985. Asked for another look at that design. (8/9/96) No change. 2/23/01; repairs needed, see memo this date. 5/14/02; new repair list.	5/8/2003
2407	Roxborough Village filing 16B		<input checked="" type="checkbox"/>	2/17/1999	<input checked="" type="checkbox"/>	6/7/1999	<input checked="" type="checkbox"/>	8/1/2001	<input checked="" type="checkbox"/>	5/14/2002	2-7S-69W				Two storm sewer outfalls. 4/21/99: minor details.	5/14/2002
1652	Roxborough Village Filing No. 12-B		<input checked="" type="checkbox"/>	8/2/1995	<input checked="" type="checkbox"/>	10/5/1995	<input checked="" type="checkbox"/>	8/26/1996	<input checked="" type="checkbox"/>	5/15/2002	35-6S-69W				Two storm sewer outlets. Need status of ownership of receiving channel before final eligibility can be considered. 2/23/01; repairs needed, see memo this date. 5/15/02; District CIP project.	5/15/2002
218	Roxborough Villages		<input checked="" type="checkbox"/>	3/1/1985	<input type="checkbox"/>	8/12/1996	<input type="checkbox"/>		<input type="checkbox"/>		1,2,11-7S-69W; 35-6S-69W				MDP apprvd; problems w/channel & box culvert design (7/29/85); problem w/culvert extension & erosion cntrl d/s of Rampart Range Rd. (8/12/96) Approval rescinded because it was 11-years old. See #2021	8/12/1996
634	Southdowns at Roxborough (Fire Stat		<input type="checkbox"/>	12/16/1988	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>		12-7S-69W				Problems w/ proposed box culvert...	12/19/1988

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT OK? DATE	DESIGN OK? DATE	CNSTRCTN OK? DATE	ELIGIBLE YES DATE	SEC TS R	STATIONING DS US	STATION REFERENCE	COMMENTS	LAST UPDATE
968	Southdowns at Roxborough (Phase A)		<input type="checkbox"/> 9/9/1988	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	12-7S-69W			Basin diversion proposed...	9/16/1988
MARCY GULCH											
87	Blakeland		<input checked="" type="checkbox"/> 9/2/1987	<input checked="" type="checkbox"/> 8/3/1994	<input checked="" type="checkbox"/> 8/11/1995	<input checked="" type="checkbox"/> 4/30/1996	6-6S-68W			10/7/96: Site plan for filings 6 & 7B could adversely impact existing eligible channel.	10/7/1996
703	Chatfield Industrial Park		<input checked="" type="checkbox"/> 6/12/1981	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	6-6S-68W				10/5/1987
1611	Douglas County High School No. 4		<input checked="" type="checkbox"/> 5/15/1995	<input checked="" type="checkbox"/> 5/15/1995	<input checked="" type="checkbox"/> 7/7/1997	<input checked="" type="checkbox"/> 6/26/2007	16-6S-68W			One storm sewer outlet. After the fact review and acceptance.	7/9/2007
58	Highlands Ranch (Culvert 7)		<input checked="" type="checkbox"/> 2/11/1986	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> 11/26/2007	8-6S-68W	103+00	125+00	Marcy Gulch FHAD Includes FHAD Reach 4; 211 a.f. detention basin proposed. Accepted due to 2007 DCM project.	11/26/2007
208	Highlands Ranch (Marcy Gulch MP)		<input checked="" type="checkbox"/> 12/5/1985	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5,8-6S-68W	599+00	617+92	Marcy Gulch FHAD Master Plan of Drainage o.k. for detention planning...	6/11/1986
211	Highlands Ranch (Marcy Gulch MP)		<input checked="" type="checkbox"/> 12/5/1985	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5,8,9-6S-68W; 14,15,16-6S-68W	49+00	333+20	Marcy Gulch FHAD Master Plan of Drainage o.k. for detention planning...	6/11/1986
210	Highlands Ranch (Marcy Gulch MP)		<input checked="" type="checkbox"/> 12/5/1985	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	15-6S-68W	398+40	411+38	Marcy Gulch FHAD Master Plan of Drainage o.k. for detention planning...	6/11/1986
209	Highlands Ranch (Marcy Gulch MP)		<input checked="" type="checkbox"/> 12/5/1985	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	15-6S-68W	499+33	508+60	Marcy Gulch FHAD Master Plan of Drainage o.k. for detention planning...	6/11/1986
1091	Highlands Ranch (Plan #111)		<input checked="" type="checkbox"/> 4/9/1991	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	8,9-6S-68W			Open floodplain and storm sewer outlets.	4/10/1991
1092	Highlands Ranch (Plan #112)		<input checked="" type="checkbox"/> 1/7/1992	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	8,9-6S-68W			Three storm sewer outfalls.	1/10/1992
1093	Highlands Ranch (Plan #113)		<input checked="" type="checkbox"/> 8/27/1991	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	15-6S-68W			Three storm sewer outlets.	8/27/1991
1136	Highlands Ranch (Plan #114)		<input checked="" type="checkbox"/> 11/28/1990	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	14-6S-68W			Storm drain outlet works only.	12/12/1990
773	Highlands Ranch (Plan #81)		<input checked="" type="checkbox"/> 10/9/1987	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5-6S-68W	53+00	66+00	Marcy Gulch FHAD Two storm sewer outfalls; existing x-ing to Marcy Gulch Wastewater Treatment Plant questioned...	10/12/1987
1121	Highlands Ranch (Plan #97)		<input checked="" type="checkbox"/> 10/12/1990	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	14,15-6S-68W				11/1/1990
1027	Highlands Ranch (Plan #97)		<input checked="" type="checkbox"/> 9/21/1989	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	10,11,14-6S-68W; 15-6S-68W			Storm sewer outlets only.	9/25/1989

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT OK? DATE	DESIGN OK? DATE	CNSTRCTN OK? DATE	ELIGIBLE YES DATE	SEC TS R	STATIONING DS US	STATION REFERENCE	COMMENTS	LAST UPDATE
1569	Highlands Ranch Blvd.		<input type="checkbox"/> 2/13/1995	<input type="checkbox"/> 2/13/1995	<input type="checkbox"/>	<input type="checkbox"/>	9-6S-68W			One storm sewer outlet.	2/13/1995
1573	Highlands Ranch Broadway Ex. Culv		<input checked="" type="checkbox"/> 6/26/1995	<input checked="" type="checkbox"/> 6/26/1995	<input checked="" type="checkbox"/> 4/16/1997	<input type="checkbox"/> 9/7/2006	15-6S-68W			Dissipator structure only. 9/7/06; repairs needed for final acceptance (see letter this date).	9/7/2006
2492	Highlands Ranch Douglas Co H S No.		<input type="checkbox"/> 9/2/1999	<input checked="" type="checkbox"/> 11/22/1999	<input checked="" type="checkbox"/> 12/31/2007	<input type="checkbox"/> 12/31/2007	14-6S-68W			One storm sewer outfall. Repair list.	12/31/2007
3490	Highlands Ranch F 118-N (Pond D1)		<input type="checkbox"/>	<input checked="" type="checkbox"/> 10/3/2005	<input type="checkbox"/>	<input type="checkbox"/>	15-6S-68W			Pond D 1.	4/3/2008
2402	Highlands Ranch Filing 118-L		<input checked="" type="checkbox"/> 2/8/1999	<input checked="" type="checkbox"/> 2/8/1999	<input checked="" type="checkbox"/> 6/29/2004	<input checked="" type="checkbox"/> 8/27/2004	14,15-6S-68W			2/8/99: Const. Plans approved. 3/8/99: Floodplain in open space tract. Final plat.	8/27/2004
3374	Highlands Ranch Filing 118-L Living		<input checked="" type="checkbox"/> 10/28/2005	<input checked="" type="checkbox"/> 10/28/2005	<input checked="" type="checkbox"/> 11/17/2008	<input type="checkbox"/>	15-6S-68W			One storm sewer outfall at Living Way Fellowship Church.	11/17/2008
3334	Highlands Ranch Filing 118-S Culver		<input checked="" type="checkbox"/> 4/20/2005	<input checked="" type="checkbox"/> 4/20/2005	<input checked="" type="checkbox"/> 9/24/2007	<input checked="" type="checkbox"/> 9/24/2007	15-6S-68W			One storm sewer outfall.	9/24/2007
1482	Highlands Ranch Filing No. 111-B		<input checked="" type="checkbox"/> 5/17/1994	<input checked="" type="checkbox"/> 8/16/1994	<input checked="" type="checkbox"/> 3/3/1999	<input checked="" type="checkbox"/> 8/7/2007	9-6S-68W			Two storm sewer outlets. See also ID No. 1481. Covered under DCM Marcy Gulch improvement project.	8/7/2007
1571	Highlands Ranch Filing No. 111-C		<input checked="" type="checkbox"/> 4/20/1995	<input checked="" type="checkbox"/> 4/20/1995	<input checked="" type="checkbox"/> 7/8/1999	<input checked="" type="checkbox"/> 8/7/2007	8-6S-68W			One storm sewer outlet. Covered under UD DCM Marcy Gulch improvement project.	8/7/2007
1492	Highlands Ranch Filing No. 112-A		<input checked="" type="checkbox"/> 12/12/1994	<input checked="" type="checkbox"/> 12/12/1994	<input checked="" type="checkbox"/> 7/30/2007	<input checked="" type="checkbox"/> 7/30/2007	8,9-6S-68W			Four storm sewer outfalls out of which one is eligible under project No. 2331 and one under CIP.	7/30/2007
2331	Highlands Ranch Filing No. 112-A		<input checked="" type="checkbox"/> 7/15/1998	<input checked="" type="checkbox"/> 7/15/1998	<input checked="" type="checkbox"/> 12/5/2000	<input checked="" type="checkbox"/> 10/1/2001	8,9-6S-68W			one storm sewer outfall, see also record 1492	10/1/2001
1557	Highlands Ranch Filing No. 113-D		<input checked="" type="checkbox"/> 12/2/1994	<input checked="" type="checkbox"/> 5/15/1995	<input checked="" type="checkbox"/> 4/30/1996	<input checked="" type="checkbox"/> 11/9/1999	10-6S-68W			Three storm sewer outlets.	11/9/1999
1490	Highlands Ranch Filing No. 118-A		<input checked="" type="checkbox"/> 6/13/1994	<input checked="" type="checkbox"/> 7/21/1994	<input checked="" type="checkbox"/> 9/4/1996	<input checked="" type="checkbox"/> 10/14/2004	16-6S-68W			One storm sewer outlet.	10/14/2004
1554	Highlands Ranch Filing No. 118-B		<input checked="" type="checkbox"/> 2/8/1995	<input checked="" type="checkbox"/> 4/6/1995	<input checked="" type="checkbox"/> 3/7/1996	<input checked="" type="checkbox"/> 6/26/2007	16-6S-68W			One storm sewer outlet. After the fact review and acceptance.	7/9/2007
1626	Highlands Ranch Filing No. 118-F		<input checked="" type="checkbox"/> 5/15/1995	<input checked="" type="checkbox"/> 5/15/1995	<input checked="" type="checkbox"/> 2/26/1996	<input checked="" type="checkbox"/> 6/28/1996	16-6S-68W			One storm sewer outlet.	6/28/1996
2006	Highlands Ranch Filing No. 118-G		<input checked="" type="checkbox"/> 1/9/1996	<input checked="" type="checkbox"/> 4/24/1996	<input checked="" type="checkbox"/> 4/16/1997	<input checked="" type="checkbox"/> 10/1/2001	15-6S-68W			Two storm sewer outlets.	10/1/2001
1511	Highlands Ranch Filing No. 119-A		<input checked="" type="checkbox"/> 6/20/1995	<input checked="" type="checkbox"/> 7/25/1995	<input checked="" type="checkbox"/> 10/7/1997	<input checked="" type="checkbox"/> 9/6/2006	14,15-6S-68W			Three storm sewer outlets. See also ID #1512.	9/6/2006
1996	Highlands Ranch Filing No. 121-B		<input checked="" type="checkbox"/> 10/5/1995	<input checked="" type="checkbox"/> 10/5/1995	<input checked="" type="checkbox"/> 12/27/1996	<input checked="" type="checkbox"/> 10/1/2001	9-6S-68W			Three storm sewer outlets.	10/1/2001

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT OK? DATE	DESIGN OK? DATE	CNSTRCTN OK? DATE	ELIGIBLE YES DATE	SEC TS R	STATIONING DS US	STATION REFERENCE	COMMENTS	LAST UPDATE
2146	Highlands Ranch Filing No. 134		<input checked="" type="checkbox"/> 5/7/1997	<input checked="" type="checkbox"/> 5/7/1997	<input checked="" type="checkbox"/> 10/7/1997	<input checked="" type="checkbox"/> 10/14/2004	8-6S-68W			One storm sewer energy dissipater.	10/14/2004
2119	Highlands Ranch Foothills Canyon Bl		<input checked="" type="checkbox"/> 1/28/1997	<input checked="" type="checkbox"/> 7/2/1998	<input checked="" type="checkbox"/> 7/8/1999	<input checked="" type="checkbox"/> 11/26/2007	8-6S-68W			Two storm sewer outfalls. Outfall from flg 111C affected by 2007 UD CIP, outfall at Town Center Dr affected by 2000 UD CIP.	11/26/2007
2198	Highlands Ranch Gateway Drive		<input checked="" type="checkbox"/> 8/27/1997	<input checked="" type="checkbox"/> 12/6/2000	<input checked="" type="checkbox"/> 9/6/2006	<input checked="" type="checkbox"/> 9/6/2006	14-6S-68W			One storm sewer outlet. Original approval 11/5/97. 9/6/06; After-the-fact review and acceptance based on 7/20/06 site visit.	9/6/2006
2372	Highlands Ranch Marcy Gulch Detent		<input checked="" type="checkbox"/> 11/10/1998	<input type="checkbox"/> 1/20/1999	<input type="checkbox"/>	<input type="checkbox"/>	8-6S-68W			At Town Center Parkway embankment. 1/20/99; need site meeting to consider corrective action at existing outlet.	1/20/1999
2414	Highlands Ranch Marcy Gulch Impro		<input checked="" type="checkbox"/> 4/21/1999	<input type="checkbox"/> 10/7/1999	<input type="checkbox"/>	<input type="checkbox"/>	14,15-6S-68W			West & East Marcy Gulch Improvements between Broadway & Wild Cat Reserve Pkwy @ Filing No. 118L.	10/25/1999
2267	Highlands Ranch Marcy Gulch Park		<input checked="" type="checkbox"/> 6/16/1998	<input checked="" type="checkbox"/> 9/10/1998	<input checked="" type="checkbox"/> 7/8/1999	<input checked="" type="checkbox"/> 8/7/2007	9-6S-68W	149+00 158+00	Marcy Gulch FHAB	Toe & bank protection, 2 GSBs, stabilization, pedestrian bridge associated with regional park. Covered under DCM Marcy Gulch improvement project.	8/7/2007
2155	Highlands Ranch Pipe 121		<input checked="" type="checkbox"/> 4/23/1997	<input checked="" type="checkbox"/> 4/23/1997	<input checked="" type="checkbox"/> 3/3/1999	<input checked="" type="checkbox"/> 2/26/2001	15-6S-68W			One storm sewer outlet.	2/23/2001
2037	Highlands Ranch Pipe 26	Un-named	<input checked="" type="checkbox"/> 4/24/1996	<input checked="" type="checkbox"/> 4/24/1996	<input checked="" type="checkbox"/> 8/26/1996	<input checked="" type="checkbox"/> 10/1/2001	15-6S-68W			One storm sewer outlet.	10/1/2001
2128	Highlands Ranch Pipe 45		<input checked="" type="checkbox"/> 4/16/1997	<input checked="" type="checkbox"/> 4/16/1997	<input checked="" type="checkbox"/> 5/27/1997	<input checked="" type="checkbox"/> 10/1/2001	5-6S-68W			One storm sewer outlet.	10/1/2001
2139	Highlands Ranch Pipe 61		<input checked="" type="checkbox"/> 3/14/1997	<input checked="" type="checkbox"/> 3/14/1997	<input checked="" type="checkbox"/> 10/7/1997	<input checked="" type="checkbox"/> 6/2/2003	5-6S-68W			One energy dissipater.	6/2/2003
2214	Highlands Ranch Wildcat Reserve Par		<input checked="" type="checkbox"/> 8/12/1998	<input checked="" type="checkbox"/> 8/12/1998	<input checked="" type="checkbox"/> 4/4/2001	<input checked="" type="checkbox"/> 7/30/2007	14-6S-68W			Two roadway crossings w/channelization u/s & d/s. Pipe not eligible. See also 2215.	7/30/2007
1487	Plaza Drive Detention Pond		<input checked="" type="checkbox"/> 5/26/1994	<input type="checkbox"/> 6/28/1994	<input type="checkbox"/>	<input type="checkbox"/>	8-6S-68W			Will submit as-builts per telecon w/ Cliff Brockman.	7/1/1994
McLELLAN RESERVOIR											
3410	Highlands Ranch Filing 152, Lot 1	Un named	<input type="checkbox"/> 8/23/2006	<input type="checkbox"/> 8/23/2006	<input type="checkbox"/>	<input type="checkbox"/>	4-6S-68W			BMW Dealership. One outfall to Highlands Ranch PA 84 Detention Pond (ID 2400). 8/23/2006; plans & rpt.	8/23/2006

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT OK? DATE	DESIGN OK? DATE	CNSTRCTN OK? DATE	ELIGIBLE YES DATE	SEC TS R	STATIONING DS US	STATION REFERENCE	COMMENTS	LAST UPDATE
2400	Highlands Ranch PA 84 Detention Po	Un named	<input checked="" type="checkbox"/> 2/5/1999	<input checked="" type="checkbox"/> 5/25/1999	<input checked="" type="checkbox"/> 5/8/2003	<input checked="" type="checkbox"/> 6/2/2003	4-6S-68W			Regional flood contol & water quality enhancement pond. 2/5/99: needs several WQ features added. 4/6/99: forebay details. See also record 2473	6/2/2003
2527	Highlands Ranch Pipe 53	un-named	<input checked="" type="checkbox"/> 12/16/1999	<input checked="" type="checkbox"/> 1/28/2000	<input checked="" type="checkbox"/> 11/13/2000	<input checked="" type="checkbox"/> 5/30/2001	4-6S-68W			12/16/99: minor details	5/30/2001
NEWLIN GULCH											
702	Arapahoe Riding & Training Center		<input checked="" type="checkbox"/> 10/23/1984	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	20-6S-66W	153+50	166+25	Happy Canyon FHAD	10/5/1987
3261	Canyons Golf Club	Mesa	<input type="checkbox"/> 8/31/2004	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	12-7S-67W	0+00	48+00	Newlin OSP	8/31/04: SIP
3260	Canyons Golf Club	Spring	<input type="checkbox"/> 8/31/2004	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	11-7S-67W	0+00	15+00	Newlin OSP	8/31/04: SIP
3259	Canyons Golf Club		<input type="checkbox"/> 8/31/2004	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2-7S-67W	415+00	445+00	Newlin OSP	8/31/04: SIP
3262	Canyons Golf Club	South Newlin Gulch	<input type="checkbox"/> 8/31/2004	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-7S-67W	68+00	105+00	Newlin OSP	8/31/04: SIP
214	Jordan Business Park		<input checked="" type="checkbox"/> 10/10/1985	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	9-6S-66W	0+00	25+50	Happy Canyon Creek FHAD	Prelim. Drainage Study o.k...
3250	Meridian Villages		<input type="checkbox"/> 8/16/2004	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	18-6S-66W	184+00	191+00	Happy Canyon FHAD	8/16/04: plat.
1489	Newlin Gulch, Jordan to Stonegate Ph		<input checked="" type="checkbox"/> 6/9/1994	<input checked="" type="checkbox"/> 6/9/1994	<input checked="" type="checkbox"/> 3/22/1995	<input type="checkbox"/>	17-6S-66W	58+00	105+00	Happy Canyon FHAD	Divided in two. See #2027. Storm sewer outlets NOT eligible. See 1357, 1361, and there are others.
2027	Newlin Gulch, Jordan to Stonegate Ph		<input checked="" type="checkbox"/> 6/9/1994	<input checked="" type="checkbox"/> 6/9/1994	<input checked="" type="checkbox"/> 3/7/1996	<input type="checkbox"/> 4/22/1997	16,17-6S-66W	48+00	58+00	Happy Canyon FHAD	Divided in two. See #1489 for Phase 1. 4/22/97: Reveg. not acceptable and a storm sewer outlet has "appeared."
220	Stonegate		<input checked="" type="checkbox"/> 5/10/1985	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	16,17-6S-66W	25+20	124+50	Happy Canyon Creek FHAD	Master Drainage Plan approved...
695	Stonegate	unnamed (several)	<input type="checkbox"/> 4/21/1982	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	16,17-6S-66W				10/5/1987
694	Stonegate		<input type="checkbox"/> 4/21/1982	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	16,17-6S-66W	25+25	124+50	Happy Canyon FHAD	Duplicate record.
1318	Stonegate		<input checked="" type="checkbox"/> 2/16/1993	<input checked="" type="checkbox"/> 3/2/1993	<input checked="" type="checkbox"/> 2/7/1995	<input type="checkbox"/>	17-6S-66W	107+00	124+50	Happy Canyon FHAD	
1452	Stonegate Elementary School #20		<input checked="" type="checkbox"/> 3/9/1994	<input checked="" type="checkbox"/> 3/9/1994	<input type="checkbox"/>	<input checked="" type="checkbox"/> 2/12/2008	17-6S-66W	100+00	101+00	Happy Canyon FHAD	One outlet structure only. After the fact review and acceptance.
1278	Stonegate Filing 15		<input checked="" type="checkbox"/> 8/13/1992	<input checked="" type="checkbox"/> 3/16/1994	<input checked="" type="checkbox"/> 2/12/2008	<input checked="" type="checkbox"/> 2/12/2008	17-6S-66W	53+00	124+50	Happy Canyon Creek FHAD	Drop structures and one storm sewer outfall.
1317	Stonegate Filing 5 C	B1	<input checked="" type="checkbox"/> 2/16/1993	<input checked="" type="checkbox"/> 3/2/1993	<input checked="" type="checkbox"/> 2/7/1995	<input checked="" type="checkbox"/> 2/12/2008	17-6S-66W				One storm sewer outfall.

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT OK? DATE	DESIGN OK? DATE	CNSTRCTN OK? DATE	ELIGIBLE YES DATE	SEC TS R	STATIONING DS US	STATION REFERENCE	COMMENTS	LAST UPDATE
1232	Stonegate Filing 5-C		<input type="checkbox"/> 3/6/1992	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	17-6S-66W	105+00 125+00	Happy Canyon FHAD		3/9/1992
1367	Stonegate Filing No. 15	Jordan Road Tributary	<input checked="" type="checkbox"/> 6/25/1993	<input checked="" type="checkbox"/> 3/16/1994	<input checked="" type="checkbox"/> 2/7/1995	<input checked="" type="checkbox"/> 7/19/1996	17-6S-66W			Channel relocation.	7/19/1996
1357	Stonegate Filing No. 15A		<input type="checkbox"/> 9/30/1993	<input type="checkbox"/> 9/30/1993	<input type="checkbox"/>	<input type="checkbox"/> 2/12/2008	17-6S-66W			Two storm sewer outlets. After the fact review, repair list.	2/12/2008
1361	Stonegate Filing No. 15C		<input type="checkbox"/> 9/30/1993	<input type="checkbox"/> 9/30/1993	<input type="checkbox"/>	<input type="checkbox"/> 2/12/2008	17-6S-66W			One storm sewer outfall. After the fact review, repair list issued.	2/12/2008
1392	Stonegate Filing No. 15-G	Jordan Road Trib.	<input checked="" type="checkbox"/> 10/8/1993	<input type="checkbox"/> 10/8/1993	<input type="checkbox"/>	<input checked="" type="checkbox"/> 2/12/2008	17-6S-66W			Storm sewer outlet. After the fact review.	2/12/2008
1591	Stonegate Filing No. 19		<input type="checkbox"/> 3/29/1995	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	16-6S-66W	31+00 50+00	Newlin Gulch OSP	Opposite Filing 21. #1562	3/30/1995
1562	Stonegate Filing No. 21		<input type="checkbox"/> 12/29/1994	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	16-6S-66W	31+00 50+00	Newlin Gulch OSP		12/29/1994
1563	Stonegate Filing No. 21	Lower Jordan Rd.	<input type="checkbox"/> 12/29/1994	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	16-6S-66W		Newlin Gulch OSP		12/29/1994
1606	Stonegate Filing No. 21-A	Lower Jordan Road	<input type="checkbox"/> 4/14/1995	<input type="checkbox"/> 4/14/1995	<input type="checkbox"/>	<input checked="" type="checkbox"/> 2/12/2008	16-6S-66W			One culvert outlet. See also ID # 1563. After the fact review.	2/12/2008
1605	Stonegate Filing No. 21-C		<input checked="" type="checkbox"/> 7/20/1995	<input checked="" type="checkbox"/> 10/18/1995	<input checked="" type="checkbox"/> 3/10/1997	<input checked="" type="checkbox"/> 2/12/2008	16-6S-66W			One storm sewer outlet. See also ID # 1562 for Newlin Gulch.	2/12/2008
1619	Stonegate Filing No. 21-D	Lower Jordan Road	<input checked="" type="checkbox"/> 4/28/1995	<input type="checkbox"/> 4/28/1995	<input type="checkbox"/>	<input checked="" type="checkbox"/> 2/12/2008	16-6S-66W			One box culvert outlet. After the fact review.	2/12/2008
1428	Stonegate No. 17		<input type="checkbox"/> 1/25/1994	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	17-6S-66W	53+50 62+00	Happy Canyon FHAD		1/26/1994
1225	Stonegate No. 9	Un-named	<input checked="" type="checkbox"/> 1/29/1992	<input checked="" type="checkbox"/> 1/29/1992	<input checked="" type="checkbox"/> 6/23/1995	<input type="checkbox"/>	17-6S-66W			Channel and drop structure. See also ID No. 1224.	6/23/1995
1224	Stonegate No. 9		<input checked="" type="checkbox"/> 1/29/1992	<input checked="" type="checkbox"/> 1/29/1992	<input checked="" type="checkbox"/> 6/23/1995	<input type="checkbox"/>	17-6S-66W	60+00 76+00	Happy Canyon FHAD	One storm sewer outlet.	6/23/1995
PINEY CREEK											
2756	Spring Creek Ranch	Trib to Tenderfoot G	<input checked="" type="checkbox"/> 3/6/2001	<input checked="" type="checkbox"/> 8/27/2003	<input checked="" type="checkbox"/> 3/7/2006	<input checked="" type="checkbox"/> 3/7/2006	17-6S-65W			3/6/01: Sketch plan. 2/21/02; Const plans & rpt. 4/24/02; const plans & rpt. 2/6/03; plans & rpt. 3/26/03; plans & rpt.	3/7/2006
2755	Spring Creek Ranch	Tenderfoot Gulch	<input checked="" type="checkbox"/> 3/6/2001	<input checked="" type="checkbox"/> 8/27/2003	<input checked="" type="checkbox"/> 3/7/2007	<input checked="" type="checkbox"/> 3/7/2007	17-6S-65W	68+75 76+00	Piney Creek Tribs FHAD	3/6/01: Sketch plan. 2/21/01; const plans & rpt. 4/24/02; const plans & rpt. 2/6/03; plans & rpt. 3/26/03; plans & rpt.	3/7/2007
PLUM CREEK											
1300	Highlands Ranch Filing No. 110-D	Plum Cr. Retention P	<input type="checkbox"/> 12/7/1992	<input type="checkbox"/> 12/7/1992	<input type="checkbox"/> 12/7/1992	<input type="checkbox"/> 12/7/1992	17-6S-68W			Not on a major drainageway.	12/7/1992
689	Owens Industrial Center		<input type="checkbox"/> 8/17/1981	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3-3S-68W				10/2/1987

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT OK? DATE	DESIGN OK? DATE	CNSTRCTN OK? DATE	ELIGIBLE YES DATE	SEC TS R	STATIONING DS US	STATION REFERENCE	COMMENTS	LAST UPDATE	
690	Owens Industrial Center	unnamed	<input type="checkbox"/> 8/17/1981	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3-3S-68W				10/2/1987	
586	Proto Construction and Paving		<input type="checkbox"/> 2/27/1987	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	29-6S-68W			404 Permit req'd; dredge fill and channelization proposed.	3/3/1987	
3388	Ready Mix Concrete (Owens Indus Pa	6600-02	<input type="checkbox"/> 2/6/2006	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3-7S-68W	967+50	974+00	Plum Creek FHAD (11/01)	2/6/06: SIP. Ignores MP.	2/15/2006
3387	Ready Mix Concrete (Owens Indus Pa		<input type="checkbox"/> 2/6/2006	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3-7S-68W		192+50	Plum Creek FHAD (11/01)	2/6/06: SIP. FP encroaches but not channel. Private ownership	2/15/2006
686	Reynolds Industrial Sub.		<input checked="" type="checkbox"/> 2/9/1981	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3-7S-68W					10/2/1987
682	Titan Rd. Industrial Park	unnamed	<input type="checkbox"/> 8/21/1980	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	29-6S-68W					10/2/1987
817	Westridge at Plum Creek	unnamed	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> 10/22/1987	17-6S-68W			Not a major drainageway facility. Also, a retention pond.	10/23/1987	
SADDLE ROCK RANCHES GUL												
2072	Inspiration Pointe	Saddle Rock Trib. So	<input checked="" type="checkbox"/> 8/2/1996	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-6S-66W	7+40	27+00	Piney Creek Tribs. FHAD		8/2/1996
SARA GULCH												
2117	Parker Ridge Filing No. 1		<input checked="" type="checkbox"/> 8/5/1999	<input checked="" type="checkbox"/> 8/24/2000	<input checked="" type="checkbox"/> 12/2/2002	<input checked="" type="checkbox"/> 9/25/2007	30-6S-65W			See also 2534 9/30/98; open floodplain concept, see letter for issues. 8/5/99; concept of cooperating with VOP on regional detention and major draiangeway planning are ok, need construction plans.	9/25/2007	
2534	Parker Ridge Filing No. 1	West Tributary	<input checked="" type="checkbox"/> 8/5/1999	<input checked="" type="checkbox"/> 8/24/2000	<input checked="" type="checkbox"/> 12/2/2002	<input checked="" type="checkbox"/> 9/25/2007	30-6S-65W			See also 2117 8/15/99; Trib. to Sara Gulch to receive undetained flow from Villages of Parker. Developer to provide grade stability.	9/25/2007	
3318	Parker Ridge filing No. 3		<input checked="" type="checkbox"/> 7/26/2005	<input checked="" type="checkbox"/> 7/26/2005	<input checked="" type="checkbox"/> 9/24/2007	<input checked="" type="checkbox"/> 9/24/2007	30-6S-65W			12/14/04: Preliminary plan. 3/28/05: Final plat. 5/17/05; plans & rpt.	9/24/2007	
3468	Parker Ridge Filing No. 3 Low Water		<input checked="" type="checkbox"/> 9/10/2008	<input type="checkbox"/> 2/12/2008	<input type="checkbox"/>	<input type="checkbox"/>	30-6S-65W			9/10/07: plans. 2/12/08; plans.	2/13/2008	
SCOTT GULCH												
3357	Canyons South	Unnamed	<input checked="" type="checkbox"/> 7/26/2005	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	17-7S-66W			7/26/05: Sketch plan. Only partially in District. Drainageway all in regional park.	7/26/2005	
1408	Pinery NW		<input type="checkbox"/> 8/24/1995	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	10-7S-66W			Rezone and sketch plan/	8/29/1995	

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT	DESIGN	CNSTRCTN	ELIGIBLE	SEC TS R	STATIONING		STATION	COMMENTS	LAST UPDATE
			OK? DATE	OK? DATE	OK? DATE	YES DATE		DS	US	REFERENCE		
2994	Pinery West District Roads		<input checked="" type="checkbox"/> 3/27/2002	<input checked="" type="checkbox"/> 6/12/2002	<input checked="" type="checkbox"/> 2/25/2004	<input checked="" type="checkbox"/> 5/4/2004	16-7S-66W				Culvert No. 3. 2/22/02: const plans & rpt. 3/27/02: const plans & rpt.	5/4/2004
3148	Pinery West Filing No. 1-I		<input checked="" type="checkbox"/> 8/19/2003	<input checked="" type="checkbox"/> 12/10/2003	<input checked="" type="checkbox"/> 7/2/2008	<input type="checkbox"/> 7/2/2008	16,17-7S-66W				8/19/03; plans & rpt. One outfall. Repair list.	7/2/2008
3100	Pinery West Filing No. 1-J		<input checked="" type="checkbox"/> 8/19/2003	<input checked="" type="checkbox"/> 7/30/2007	<input type="checkbox"/>	<input type="checkbox"/>	16,17-7S-66W				2/13/03: Final plat. 8/19/03; plans & rpt. 12/10/03; plans & rpt. 3/28/07; recert for original approval of 3/5/04.	7/30/2007
2996	Pinery West Scott Gulch Detention Po		<input checked="" type="checkbox"/> 10/23/2002	<input checked="" type="checkbox"/> 1/16/2003	<input checked="" type="checkbox"/> 6/21/2004	<input checked="" type="checkbox"/> 8/2/2007	16-7S-66W				See also record 2994. 6/18/02; plans & report. 10/23/02; const plans	8/2/2007
1602	Pinery West, Pradera Golf Course	Un-named	<input checked="" type="checkbox"/> 8/25/1998	<input checked="" type="checkbox"/> 10/9/2003	<input checked="" type="checkbox"/> 6/3/2005	<input checked="" type="checkbox"/> 2/12/2008	17-7S-66W				See also ID #1601. Formerly Berkshire Crossing. Original concept in 1995. New concept in 1998. 4/23/03; plans & rpt. 8/20/03; plans & rpt.	2/12/2008
1601	Pinery West, Pradera Golf Course		<input checked="" type="checkbox"/> 8/25/1998	<input checked="" type="checkbox"/> 10/9/2003	<input checked="" type="checkbox"/> 6/3/2005	<input checked="" type="checkbox"/> 2/12/2008	16,17-7S-66W				See also ID #1602. Formerly Berkshire Crossing. Original concept in 1995. New concept in 1998. 4/23/03; plans & rpt. 8/20/03; plans & rpt.	2/12/2008
3071	Scott Road		<input checked="" type="checkbox"/> 11/3/2004	<input checked="" type="checkbox"/> 4/19/2005	<input checked="" type="checkbox"/> 8/2/2007	<input checked="" type="checkbox"/> 8/2/2007	16-7S-66W				12/18/02: Rezoning and sketch plan. 6/7/04: prelim & final plat submittal. Floodplain to be owned by HOA. 7/20/04; plans & rpt, request stream stab. 11/3/04; plans & rpt. 2/8/05; plans & rpt.	8/2/2007
SOUTH PLATTE RIVER												
688	Reservoir @ Chatfield	unnamed	<input checked="" type="checkbox"/> 4/22/1981	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	25-6S-69W				Two unnamed tribs.	10/2/1987
707	Warwick Springs	unnamed (2)	<input checked="" type="checkbox"/> 7/31/1984	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	25-6S-69W					10/5/1987
SPRING GULCH												
1089	Highlands Ranch (Plan # 110)		<input checked="" type="checkbox"/> 8/2/1991	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	16,17-6S-68W	58+00	104+00	Spring Gulch FHAD (Jack G. Raub report)	Floodplain and storm sewer outlets.	8/2/1991
1090	Highlands Ranch (Plan #111)		<input checked="" type="checkbox"/> 4/9/1991	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	8,17-6S-68W				Open floodplain and storm sewer outlets.	4/10/1991
1133	Highlands Ranch (Plan #115)		<input checked="" type="checkbox"/> 11/30/1990	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	16,17-6S-68W				Combined with Plan 110 in July, 1991.	12/12/1990
653	Highlands Ranch (Plan #82)		<input checked="" type="checkbox"/> 9/9/1987	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> 7/16/2007	8-6S-68W	25+00	30+00	Spring Gulch FHAD	One storm sewer outfall. Eligible due to DCM project.	7/16/2007
1015	Highlands Ranch (Plan 102)		<input checked="" type="checkbox"/> 7/25/1989	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	8,17-6S-68W				Two storm sewer outlets.	8/15/1989

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT OK? DATE	DESIGN OK? DATE	CNSTRCTN OK? DATE	ELIGIBLE YES DATE	SEC TS R	STATIONING DS US	STATION REFERENCE	COMMENTS	LAST UPDATE	
594	Highlands Ranch (Spring Gulch MP)		<input checked="" type="checkbox"/> 3/4/1987	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	8,16,17-6S-68W		Spring Gulch FHAD		3/18/1987	
2113	Highlands Ranch Culvert No. 44		<input checked="" type="checkbox"/> 7/14/1998	<input checked="" type="checkbox"/> 7/14/1998	<input checked="" type="checkbox"/> 7/8/1999	<input checked="" type="checkbox"/> 4/2/2003	16-6S-68W			Detention pond at Stone Mountain Drive. 12/3/97; comments sent. 6/15/98: Was proposed as park. Now future regional detention only.	4/2/2003	
1472	Highlands Ranch Culverts 25 & 36	Unnamed	<input type="checkbox"/> 4/28/1994	<input type="checkbox"/> 4/28/1994	<input type="checkbox"/> 4/28/1994	<input checked="" type="checkbox"/> 7/28/2008	16-6S-68W			Two culvert street crossings - transportation facilities. Conditional acceptance - repair list issued 6/26/07.	7/28/2008	
3475	Highlands Ranch Filing 118-P		<input checked="" type="checkbox"/> 10/2/2007	<input checked="" type="checkbox"/> 10/2/2007	<input type="checkbox"/>	<input type="checkbox"/>	15-6S-68W				10/2/2007	
3484	Highlands Ranch Filing 118-Q	South Tributary	<input checked="" type="checkbox"/> 12/12/2007	<input checked="" type="checkbox"/> 7/1/2008	<input type="checkbox"/>	<input type="checkbox"/>	16-6S-68W			12/12/07; plans & rpt. 3/25/08; plans & rpt.	7/1/2008	
1080	Highlands Ranch Filing 98-A		<input checked="" type="checkbox"/> 6/29/1990	<input type="checkbox"/> 6/29/1990	<input type="checkbox"/>	<input checked="" type="checkbox"/> 6/26/2007	8-6S-68W			One energy dissipator. After the fact review and acceptance.	7/9/2007	
1285	Highlands Ranch Filing No. 102-A		<input checked="" type="checkbox"/> 10/1/1992	<input checked="" type="checkbox"/> 10/21/1992	<input type="checkbox"/> 10/4/1993	<input checked="" type="checkbox"/> 6/26/2007	8-6S-68W	30+00	31+00	Spring Gulch FHAD	One energy dissipator.	8/15/2007
1250	Highlands Ranch Filing No. 110-A		<input checked="" type="checkbox"/> 2/16/1993	<input checked="" type="checkbox"/> 2/16/1993	<input checked="" type="checkbox"/> 1/4/1995	<input checked="" type="checkbox"/> 6/28/1996	17-6S-68W	62+00	63+00	Spring Gulch FHAD	One energy dissipator.	6/28/1996
1307	Highlands Ranch Filing No. 110-E		<input checked="" type="checkbox"/> 12/11/1992	<input checked="" type="checkbox"/> 12/11/1992	<input checked="" type="checkbox"/> 12/3/1993	<input checked="" type="checkbox"/> 6/28/1996	17-6S-68W	63+00	65+00	Spring Gulch FHAD	One energy dissipator.	6/28/1996
1350	Highlands Ranch Filing No. 110-G		<input checked="" type="checkbox"/> 8/27/1993	<input checked="" type="checkbox"/> 8/27/1993	<input checked="" type="checkbox"/> 2/26/1996	<input checked="" type="checkbox"/> 6/28/1996	17-6S-68W				Three storm sewer outfalls.	6/28/1996
1356	Highlands Ranch Filing No. 110-H		<input checked="" type="checkbox"/> 9/17/1993	<input checked="" type="checkbox"/> 9/17/1993	<input checked="" type="checkbox"/> 1/4/1995	<input checked="" type="checkbox"/> 2/28/1997	16-6S-68W				Two storm sewer outlets.	2/28/1997
1488	Highlands Ranch Filing No. 110-I		<input checked="" type="checkbox"/> 6/8/1994	<input checked="" type="checkbox"/> 6/8/1994	<input checked="" type="checkbox"/> 2/6/1996	<input checked="" type="checkbox"/> 2/28/1997	17-6S-68W				One storm sewer outlet.	2/28/1997
1444	Highlands Ranch Filing No. 110-J	Unnamed	<input checked="" type="checkbox"/> 2/22/1994	<input checked="" type="checkbox"/> 6/21/1994	<input checked="" type="checkbox"/> 9/9/1996	<input checked="" type="checkbox"/> 8/20/2007	16-6S-68W				Three storm sewer outfalls (see Spring Gulch also)	8/20/2007
1443	Highlands Ranch Filing No. 110-J		<input checked="" type="checkbox"/> 2/22/1994	<input checked="" type="checkbox"/> 6/20/1994	<input checked="" type="checkbox"/> 9/9/1996	<input checked="" type="checkbox"/> 8/20/2007	16-6S-68W	85+00	105+00	Spring Gulch FHAD (by Raub)	Three storm sewer outfalls (see unnamed trib. also)	8/20/2007
1286	Highlands Ranch Filing No. 111-A/98		<input checked="" type="checkbox"/> 10/1/1992	<input checked="" type="checkbox"/> 11/5/1992	<input type="checkbox"/> 10/4/1993	<input checked="" type="checkbox"/> 6/26/2007	8-6S-68W	25+00	26+00	Spring Gulch FHAD	One energy dissipator. After the fact review and acceptance.	7/9/2007
1481	Highlands Ranch Filing No. 111-B		<input checked="" type="checkbox"/> 5/17/1994	<input checked="" type="checkbox"/> 8/16/1994	<input checked="" type="checkbox"/> 3/3/1999	<input checked="" type="checkbox"/> 8/20/2007	8-6S-68W				One storm sewer outlet. See also ID No. 1482. Included in DCM Marcy Gulch Project.	8/20/2007
2077	Highlands Ranch Filing No. 118-I		<input checked="" type="checkbox"/> 8/27/1996	<input checked="" type="checkbox"/> 11/25/1996	<input checked="" type="checkbox"/> 7/7/1997	<input checked="" type="checkbox"/> 6/26/2007	16-6S-68W				One storm sewer outlet. After the fact review and acceptance.	7/9/2007

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT OK? DATE	DESIGN OK? DATE	CNSTRCTN OK? DATE	ELIGIBLE YES DATE	SEC TS R	STATIONING DS US	STATION REFERENCE	COMMENTS	LAST UPDATE	
2124	Highlands Ranch Filing No. 118-J		<input checked="" type="checkbox"/> 6/24/1997	<input checked="" type="checkbox"/> 6/24/1997	<input type="checkbox"/>	<input type="checkbox"/> 6/26/2007	15,16-6S-68W			Two storm sewer outlets. Conditional acceptance.	7/9/2007	
2591	Highlands Ranch Filing No. 118-J Re		<input type="checkbox"/> 5/4/2000	<input type="checkbox"/> 5/4/2000	<input type="checkbox"/>	<input type="checkbox"/>	15,16-6S-68W			See also 2124.	5/5/2000	
2142	Highlands Ranch Filing No. 118-K		<input checked="" type="checkbox"/> 3/20/1997	<input checked="" type="checkbox"/> 3/20/1997	<input checked="" type="checkbox"/> 5/18/2004	<input checked="" type="checkbox"/> 5/18/2004	16-6S-68W			Three storm sewer outfalls.	5/18/2004	
2585	Highlands Ranch Filing No. 118-K R		<input checked="" type="checkbox"/> 4/20/2000	<input checked="" type="checkbox"/> 2/14/2002	<input checked="" type="checkbox"/> 5/5/2004	<input checked="" type="checkbox"/> 5/5/2004	16-6S-68W			Culvert 46, one storm sewer outfall, see 2586. 4/20/00; plans, study & plat; stream stability & regional pond design should be addressed at this time.	5/5/2004	
2982	Highlands Ranch Filing No. 118-K R	un-named	<input checked="" type="checkbox"/> 5/16/2002	<input checked="" type="checkbox"/> 7/17/2002	<input checked="" type="checkbox"/> 5/5/2004	<input checked="" type="checkbox"/> 5/5/2004	16-6S-68W			Culvert 45 Extension	5/5/2004	
2586	Highlands Ranch Filing No. 118-K R	un-named	<input checked="" type="checkbox"/> 4/20/2000	<input checked="" type="checkbox"/> 2/14/2002	<input checked="" type="checkbox"/> 5/5/2004	<input checked="" type="checkbox"/> 5/5/2004	16-6S-68W			Culvert No. 45, see 2585. 4/20/00; plans, study & plat; stream stability & regional pond design should be addressed at this time. 8/24/01; drop design & regional pond design still a problem.	5/5/2004	
2189	Highlands Ranch Filing No. 122-F	Reach 1	<input checked="" type="checkbox"/> 8/12/1997	<input checked="" type="checkbox"/> 1/16/1998	<input checked="" type="checkbox"/> 4/4/2001	<input type="checkbox"/> 9/7/2006	13-6S-68W		Dad Clark FHAD (Raub)	8/12/97:Three storm sewer outlets. 10/21/97: One storm sewer outlet deleted but another one added. 12/8/97: still has probs. 9/7/06; repairs needed for final acceptance (see letter this date).	9/7/2006	
1306	Highlands Ranch Wildcat Reserve Pk		<input checked="" type="checkbox"/> 12/11/1992	<input checked="" type="checkbox"/> 1/12/1993	<input checked="" type="checkbox"/> 1/9/1996	<input type="checkbox"/> 6/28/1996	17-6S-68W	59+00	60+00	Spring Gulch FHAD	One energy dissipator.	6/28/1996
732	Park 85		<input type="checkbox"/> 3/7/1984	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	7-6S-68W			Filed under Highlands Ranch off site.	10/6/1987	
1497	Split Rail Fence Co.		<input type="checkbox"/> 11/14/1995	<input type="checkbox"/> 11/14/1995	<input type="checkbox"/>	<input type="checkbox"/> 1/22/2008	7-6S-68W			Outfall to Highline Canal-not acceptable.	1/22/2008	
STERLING GULCH												
563	Lawrence Development	un-named	<input checked="" type="checkbox"/> 7/27/1987	<input type="checkbox"/> 1/27/2000	<input type="checkbox"/>	<input type="checkbox"/>	29-6S-68W					1/27/2000
SULPHUR GULCH												
2418	Bell Cross Ranch	Hope Gulch	<input checked="" type="checkbox"/> 10/5/2000	<input checked="" type="checkbox"/> 3/28/2002	<input checked="" type="checkbox"/> 5/30/2003	<input checked="" type="checkbox"/> 7/11/2007	18-6S-65W				3/16/99: Rezoning. 10/5/00: Prelim. Plan. 11/30/01; plans & report. 3/4/02; plans and rpt.	7/11/2007
700	Canyon Ranch Estates		<input checked="" type="checkbox"/> 5/8/1978	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	21-6S-66W	0+00	9+00	Happy Canyon FHAD	Grandfathered in.	10/5/1987
2154	DougCo Elementary School No. 24		<input checked="" type="checkbox"/> 4/22/1997	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	23-6S-66W				Two storm sewer outlets.	4/22/1997
2472	Eagle Pointe	Unnamed	<input type="checkbox"/> 8/10/1999	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	14-6S-66W				Contains portion of SCS dam and flood pool.	8/9/1999

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT OK? DATE	DESIGN OK? DATE	CNSTRCTN OK? DATE	ELIGIBLE YES DATE	SEC TS R	STATIONING DS US	STATION REFERENCE	COMMENTS	LAST UPDATE	
683	Parker Crossroads	unnamed	<input type="checkbox"/> 8/18/1981	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	22-6S-66W				10/2/1987	
2844	Rancho Montecito	North Tomahawk Gu	<input checked="" type="checkbox"/> 7/28/2004	<input checked="" type="checkbox"/> 7/28/2004	<input checked="" type="checkbox"/> 9/24/2007	<input checked="" type="checkbox"/> 9/24/2007	20-6S-65W	9+50	20+00	Sulphur Gulch OSP	11/1/01: Final plat. 7/28/04; fax submittal for grade controls.Two outfalls and one check structure.	9/24/2007
2843	Rancho Montecito	South Tomahawk Gu	<input checked="" type="checkbox"/> 7/28/2004	<input checked="" type="checkbox"/> 7/28/2004	<input checked="" type="checkbox"/> 9/24/2007	<input checked="" type="checkbox"/> 9/24/2007	20-6S-65W	8+50	14+00	Sulphur Gulch OSP	11/1/01: Final plat. 7/28/04; fax submittal for grade controls.One oufall and three check structures.	9/24/2007
708	West Parker Commercial		<input type="checkbox"/> 8/18/1981	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	22-6S-66W	29+00	39+60	Happy Canyon FHAD		10/5/1987
TALLMAN GULCH												
2735	Tallman Gulch		<input checked="" type="checkbox"/> 5/4/2006	<input checked="" type="checkbox"/> 5/4/2006	<input checked="" type="checkbox"/> 5/25/2011	<input type="checkbox"/>	31-6S-65W; 6-7S-65W	235+00	265+00	Sulphur/Tallman OSP	11/15/00: Rezoning. 1/5/01: Sketch plan. 3/28/05: Sketch plan. Still haven't addressed any comments. 3/9/06; const plans, no rpt.Repair list	5/25/2011
3319	Tallman Gulch	Goldsmith	<input checked="" type="checkbox"/> 5/4/2006	<input checked="" type="checkbox"/> 11/9/2007	<input type="checkbox"/>	<input type="checkbox"/>	31-6S-65W	0+00	22+00	Sulphur/Tallman OSP	11/15/00: Rezoning. 1/5/01: Sketch plan. 3/28/05: Sketch plan. Still haven't addressed any comments. 3/9/06; const plans, no rpt. 5/4/06; original approval. 11/9/07; Muller redesign approved.	11/9/2007
TIMBERS CREEK												
2259	Pinery Filing No. 23		<input checked="" type="checkbox"/> 6/24/1999	<input checked="" type="checkbox"/> 6/24/1999	<input checked="" type="checkbox"/> 4/3/2003	<input checked="" type="checkbox"/> 4/3/2003	13-7S-66W				On-line detention & channel stabilization. Four outfalls approved under Filing 23A (see also 2330 & 2391) will not be eligible until stabilization is complete under Filing 23B.	4/3/2003
2330	Pinery Filing No. 23-A		<input checked="" type="checkbox"/> 8/18/1998	<input checked="" type="checkbox"/> 8/18/1998	<input checked="" type="checkbox"/> 4/3/2003	<input checked="" type="checkbox"/> 4/3/2003	13-7S-66W				4 storm sewer outfalls only, will not be eligible until channel stabilization is complete, see also 2259 & 2391.	4/3/2003
2391	Pinery Filing No. 23-B		<input checked="" type="checkbox"/> 6/24/1999	<input checked="" type="checkbox"/> 6/24/1999	<input checked="" type="checkbox"/> 4/3/2003	<input checked="" type="checkbox"/> 4/3/2003	13-7S-66W				1/20/99: Floodplain in open space but no attempt made for maint. elig. yet (see also 2259 & 2330). 2/17/99: very incomplete plan and rpt submittal. 4/22/99: basis of hydrology is unclear.	4/3/2003
2517	Pinery Filing No. 24-A		<input checked="" type="checkbox"/> 11/2/2000	<input checked="" type="checkbox"/> 12/5/2000	<input checked="" type="checkbox"/> 4/3/2003	<input type="checkbox"/>	13-7S-66W; 18-7S-65W				11/22/99: Preliminary Plan. Open FP but no info on ownership and maint. respon. 6/8/00; Plat, Construction Plans & Study. 8/31/00; const plans. 11/2/00;const plans minor revisions. See also 2729.	4/3/2003

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT		DESIGN		CNSTRCTN		ELIGIBLE		STATIONING		STATION REFERENCE	COMMENTS	LAST UPDATE				
			OK?	DATE	OK?	DATE	OK?	DATE	YES	DATE	SEC	TS R				DS	US		
2729	Pinery Filing No. 24-B		<input checked="" type="checkbox"/>	8/31/2000	<input checked="" type="checkbox"/>	6/18/2001	<input checked="" type="checkbox"/>	4/3/2003	<input type="checkbox"/>					13-7S-66W; 18-7S-65W	See also 2517, channel stabilization one outfall and one roadway crossing. 8/31/00; const plans. 12/5/00; const plans minor revisions. 4/17/01; det pond outlet problem.	4/3/2003			
3150	Pinery Filing No. 27		<input checked="" type="checkbox"/>	8/18/2003	<input checked="" type="checkbox"/>	4/19/2004	<input type="checkbox"/>		<input type="checkbox"/>					18-7S-65W	Two storm sewer outfalls.	4/19/2004			
2784	Pinery Parkway Crossing at Timbers		<input checked="" type="checkbox"/>	8/31/2000	<input checked="" type="checkbox"/>	4/18/2001	<input checked="" type="checkbox"/>	4/4/2003	<input type="checkbox"/>					13-7S-66W; 18-7S-65W		4/4/2003			
3247	Pinery Sales and Information Center		<input checked="" type="checkbox"/>	7/29/2004	<input checked="" type="checkbox"/>	7/29/2004	<input type="checkbox"/>		<input type="checkbox"/>					18-7S-65W	One storm sewer outfall to Timbers Creek.	8/4/2004			
WILLOW CREEK (ARAPCO)																			
681	Bradbury 417		<input checked="" type="checkbox"/>	3/29/1983	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>					10-6S-67W	335+00	380+00	Little Dry MP	Zoning. Leaving FP in natural condition.	10/2/1987
645	Carriage Club	Cook Creek	<input checked="" type="checkbox"/>	8/17/1987	<input type="checkbox"/>	8/17/1987	<input type="checkbox"/>		<input type="checkbox"/>					16-6S-67W	63+00	70+00	Little Dry Creek MP	Extends upstream of master plan study limits.	8/18/1987
1593	Carriage Club Estates	Cook Creek	<input checked="" type="checkbox"/>	3/16/1998	<input checked="" type="checkbox"/>	3/16/1998	<input type="checkbox"/>		<input type="checkbox"/>					16-6S-67W				Line A storm sewer outlet to Cook Cr.	3/16/1998
1541	Carriage Club Filing No. 2	Cook Creek	<input checked="" type="checkbox"/>	2/6/1996	<input checked="" type="checkbox"/>	2/6/1996	<input checked="" type="checkbox"/>	12/30/1996	<input checked="" type="checkbox"/>	11/15/1999				16-6S-67W					12/30/1996
2051	Carriage Club Filing No. 3	Cook Creek	<input checked="" type="checkbox"/>	6/4/1996	<input checked="" type="checkbox"/>	12/30/1996	<input checked="" type="checkbox"/>	1/10/2000	<input type="checkbox"/>					16-6S-67W					1/25/2000
1592	Carriage Club South	Cook Creek	<input type="checkbox"/>	3/28/1995	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>					16-6S-67W					3/30/1995
1324	Centennial Ridge Filing 3	Trib. to Cook Creek	<input type="checkbox"/>	3/5/1993	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>					16-6S-67W				Can't tell if drainageway involved from info presented.	3/17/1993
706	Green Meadows (Park Meadows file)		<input checked="" type="checkbox"/>	11/14/1983	<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>					4-6S-67W	279+00	301+00	Little Dry Cr. MP		10/5/1987
1972	Green Meadows Apartments		<input checked="" type="checkbox"/>	2/14/1996	<input checked="" type="checkbox"/>	2/14/1996	<input checked="" type="checkbox"/>	9/25/1997	<input type="checkbox"/>					4-6S-67W	277+00	300+00	Little Dry Cr. MP (1974)	One storm sewer outlet.	9/25/1997
2222	Heritage Hills Filing No. 1-C Safeway		<input type="checkbox"/>	11/6/1997	<input type="checkbox"/>	11/6/1997	<input type="checkbox"/>		<input type="checkbox"/>					10-6S-67W				Two storm sewer outlets.	11/6/1997
2223	Heritage Hills Filing No. 1-D		<input checked="" type="checkbox"/>	7/13/1998	<input checked="" type="checkbox"/>	7/13/1998	<input checked="" type="checkbox"/>	7/8/1999	<input type="checkbox"/>	8/13/2001				10-6S-67W	338+00	358+00	Little Dry Creek MP (1974)	Open FP (no maint. Access or erosion considerations) and 2 storm sewer outlets. 7/13/98: outfalls approved with channel improvements, see 2249.	4/20/1999
2485	Heritage Hills Filing No. 1-F		<input checked="" type="checkbox"/>	9/7/1999	<input checked="" type="checkbox"/>	11/5/1999	<input type="checkbox"/>		<input type="checkbox"/>					10-6S-67W				See also 2249	11/5/1999
2721	Heritage Hills Filing No. 1-I		<input checked="" type="checkbox"/>	4/9/2001	<input checked="" type="checkbox"/>	4/9/2001	<input type="checkbox"/>		<input type="checkbox"/>					10-6S-67W				See also 2249, two storm sewer outfalls. 11/21/00: poor alignment, poor design. 1/23/01; no improvement	4/16/2001

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT OK? DATE	DESIGN OK? DATE	CNSTRCTN OK? DATE	ELIGIBLE YES DATE	SEC TS R	STATIONING DS US	STATION REFERENCE	COMMENTS	LAST UPDATE
1365	Heritage Summit		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	10-6S-67W	311+00 380+00	Little Dry Creek MP	Pre-design conference.	7/14/1993
213	Highlands Ranch (55A & 58A)	Spring Creek	<input checked="" type="checkbox"/> 9/10/1985	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5-6S-67W	60+00	Little Dry Creek MP	Detention concept o.k.; no floodplain info. in report...	6/11/1986
1273	Highlands Ranch Culvert 32	Spring Creek	<input checked="" type="checkbox"/> 9/11/1992	<input checked="" type="checkbox"/> 9/11/1992	<input checked="" type="checkbox"/> 10/3/1994	<input checked="" type="checkbox"/> 5/16/1996	5-6S-67W				5/16/1996
1272	Highlands Ranch Culvert 33	Spring Creek	<input checked="" type="checkbox"/> 8/28/1992	<input checked="" type="checkbox"/> 9/11/1992	<input checked="" type="checkbox"/> 10/3/1994	<input checked="" type="checkbox"/> 5/16/1996	5-6S-67W				5/16/1996
1274	Highlands Ranch Culvert 34	Spring Creek	<input checked="" type="checkbox"/> 9/11/1992	<input checked="" type="checkbox"/> 9/11/1992	<input checked="" type="checkbox"/> 6/13/2006	<input checked="" type="checkbox"/> 6/13/2006	5-6S-67W				6/13/2006
3124	Highlands Ranch Filing 18-A C-470	Spring Creek	<input checked="" type="checkbox"/> 4/9/2003	<input checked="" type="checkbox"/> 4/9/2003	<input checked="" type="checkbox"/> 11/30/2004	<input checked="" type="checkbox"/> 7/9/2007	5-6S-67W			One storm sewer rundown to Spring Creek Regional Detention Pond.	7/16/2007
1182	Highlands Ranch Filing 89-A	Spring Creek	<input checked="" type="checkbox"/> 9/13/1991	<input checked="" type="checkbox"/> 9/13/1991	<input checked="" type="checkbox"/> 6/13/2006	<input checked="" type="checkbox"/> 6/13/2006	5-6S-67W			Two outfall structures only.	6/13/2006
1396	Highlands Ranch Filing No. 89-B	Spring Creek	<input type="checkbox"/> 2/27/1992	<input type="checkbox"/> 2/27/1992	<input type="checkbox"/>	<input checked="" type="checkbox"/> 6/13/2006	5-6S-67W			After the fact field inspection and acceptance.	6/13/2006
1282	Highlands Ranch Filing No. 89-C	Spring Creek	<input checked="" type="checkbox"/> 9/9/1992	<input checked="" type="checkbox"/> 9/9/1992	<input checked="" type="checkbox"/> 9/27/1993	<input checked="" type="checkbox"/> 3/10/1997	5-6S-67W			Dissipator only.	3/10/1997
1301	Highlands Ranch Filing No. 89-D	Spring Creek	<input type="checkbox"/> 12/7/1992	<input type="checkbox"/> 12/7/1992	<input type="checkbox"/> 12/7/1992	<input type="checkbox"/> 12/7/1992	5-6S-67W			Not on a major drainageway.	12/7/1992
1523	Highlands Ranch Pipe 3	Spring Creek	<input type="checkbox"/> 8/17/1995	<input type="checkbox"/> 8/17/1995	<input type="checkbox"/>	<input type="checkbox"/> 8/17/1995	5-6S-67W			Pipe not eligible by definition.	8/18/1995
1981	Highlands Ranch Pipe 3 Channel	Spring Creek	<input type="checkbox"/> 3/6/2002	<input type="checkbox"/> 3/6/2002	<input type="checkbox"/>	<input type="checkbox"/> 11/26/2001	5-6S-67W			Channel design fails to meet District criteria. 11/26/01; const plans. 3/6/02; plans still have same probls.	3/25/2002
772	Highlands Ranch-Columbine Medical	Spring Creek	<input type="checkbox"/> 10/1/1985	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5-6S-67W			Floodplain encroachment with no calculations to support it.	10/12/1987
361	Park Meadows	2 tribs.	<input type="checkbox"/> 7/18/1986	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3-6S-67W				9/10/1986
705	Park Meadows (Sanford Homes)	unnamed (2)	<input checked="" type="checkbox"/> 11/19/1982	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3-6S-67W				10/5/1987
216	Park Meadows Convenience Ctr.		<input type="checkbox"/> 11/8/1985	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4-6S-67W	278+00	Little Dry Creek MP	Culvert extension at Maximus Drive...	6/11/1986
2232	Park Meadows/C470 Joint Venture	Un-named	<input type="checkbox"/> 1/19/1998	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3-6S-67W			One detention pond US from a long conduit. Not eligible because mostly pipe. See also Lone Tree entry 2390	1/19/1998
336	Parkway Plaza		<input checked="" type="checkbox"/> 5/31/1984	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4-6S-67W	222+00 246+50	Little Dry Creek MP		9/3/1986
332	Rampart Range		<input checked="" type="checkbox"/> 10/2/1984	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	15-6S-67W				9/3/1986
1625	Spring Creek Regional Detention Pon	Spring Creek	<input checked="" type="checkbox"/> 7/22/1996	<input checked="" type="checkbox"/> 7/22/1996	<input checked="" type="checkbox"/> 4/16/1997	<input checked="" type="checkbox"/> 6/2/2003	5-6S-67W				6/2/2003

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT OK? DATE	DESIGN OK? DATE	CNSTRCTN OK? DATE	ELIGIBLE YES DATE	SEC	TS	R	STATIONING DS	US	STATION REFERENCE	COMMENTS	LAST UPDATE
WILLOW CREEK (DOCO)														
2690	Roxborough Park MD, Willow Ck Sa		<input type="checkbox"/> 11/21/2000	<input type="checkbox"/> 11/21/2000	<input type="checkbox"/>	<input type="checkbox"/>							Erosion repair, 9/25/00; const plans. 11/21/00; same probs.	11/27/2000
WINDMILL CREEK														
2242	13201 James E. Casey Ave.		<input checked="" type="checkbox"/> 3/16/1998	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>							3/16/98: Site plan.	3/16/1998
2775	Douglas Co Ind Park, Concord II		<input checked="" type="checkbox"/> 7/16/2001	<input checked="" type="checkbox"/> 9/27/2001	<input checked="" type="checkbox"/> 5/18/2005	<input checked="" type="checkbox"/> 5/18/2005							Lots 4, 5 & 6; one outfall to Windmill Creek (90-inch rep with impact basin) channel constructed under the UPS project.	5/18/2005
2837	Douglas Co Ind Park, Concord II		<input checked="" type="checkbox"/> 7/16/2001	<input type="checkbox"/> 9/19/2001	<input type="checkbox"/>	<input type="checkbox"/>							Lot 4 two outfalls to Windmill Creek channel constructed under the UPS project.	10/5/2001
77	Douglas County Industrial Park		<input type="checkbox"/> 5/30/1986	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>								6/10/1986
2153	North Douglas Co Ind Park, UPS		<input checked="" type="checkbox"/> 7/24/1997	<input checked="" type="checkbox"/> 3/5/1998	<input checked="" type="checkbox"/> 5/18/2005	<input checked="" type="checkbox"/> 5/18/2005							Diverting channel around their site. 7/24/97: Probs. with design. 9/30/97: Still probs with design.	5/18/2005
2758	Peoria Street Extension Project		<input checked="" type="checkbox"/> 3/6/2001	<input checked="" type="checkbox"/> 3/6/2001	<input checked="" type="checkbox"/> 5/18/2005	<input checked="" type="checkbox"/> 5/18/2005							Joint Douglas & Arapahoe Counties project. D/s connects to Centennial Airport regional detention pond.	5/18/2005

Legend

- 1/1/95 Concept, design or construction approved as of the given date.
- 1/1/95 Concept, design or construction reviewed but not approved as of the given date.
- Concept, design, construction or final eligibility not yet considered.
- 1/1/95 Project not eligible for District maintenance assistance as of the given date.
- 1/1/95 **Project eligible for District maintenance assistance as of the given date.**

ID NO	PROJECT NAME	TRIBUTARY	CONCEPT		DESIGN		CNSTRCTN		ELIGIBLE		STATIONING		STATION REFERENCE	COMMENTS	LAST UPDATE
			OK?	DATE	OK?	DATE	OK?	DATE	YES	DATE	SEC	TS			